



Environmental Monitoring Report

Broadwater Power Plant 117 Pacific Highway Broadwater NSW

Licencee Cape Byron Management Pty Ltd
Address 117 Pacific Highway Broadwater NSW
EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>

This data is published as required under section 66(6) of the *Protection of the Environment Operations Act 1997*

Sampling Point:
 Licence
 Location
 EPL No
 Parameters Monitored
 Frequency & Method
 Limits

Monitoring Point 1 - No 12 Boiler Stack Emissions
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 see individual parameters in table
 Annually in accordance with EPA protocols
 see individual parameters in table



			RESULTS TABLE		
Report Number			AE 13192		
Sampling Date			16-Jul-20		
Date Received			25-Aug-20		
Date Published			27-Aug-20		
Measured Parameters dry @ STP and corrected to 7% O ₂	Units	Concentration Limit			
Average stack gas temperature	°C	Not Applicable	108.0		
Average velocity at sampling plane	m/s	Not Applicable	8.1		
Gas Volumetric Flowrate	m ³ /sec	Not Applicable	20.9		
Dry Gas Density	kg/m ³	Not Applicable	1.3		
Molecular Weight of Stack Gases	g/g mole	Not Applicable	30.1		
Moisture content	%	Not Applicable	26.7		
Concentration of carbon dioxide	%	Not Applicable	10.6		
Total Solid Particles	mg/m ³	100	70.7		
Sulphuric Acid Mist & Sulphur Trioxide as SO ₃	mg/m ³	12	5.6		
Nitrogen Oxides (NOx)	mg/m ³	500	368.0		

Sampling Point:

Licencee
 Location
 EPL No
 Parameter/s Monitored
 Frequency & Method
 Limits

Monitoring Point 2 - No 1 Cogeneration Boiler Stack Emissions

Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 see individual parameters in table
 Quarterly in accordance with EPA protocols
 see individual parameters in table

**RESULTS TABLE**

Report Number	RESULTS TABLE						
			AE 13192	AE 13401	AE 13475		
			16-Jul-20	10-Nov-20	09-Feb-21		
			25-Aug-20	23-Nov-20	02-Mar-21		
		27-Aug-20	03-Dec-20	12-Mar-21			
Measured Parameters dry @ STP and corrected to 7% O ₂	Units	Concentration Limit					
Average stack gas temperature	°C	Not Applicable	67.0	68.0	61.0		
Average velocity at sampling plane	m/s	Not Applicable	14.8	15.7	13.4		
Dry Gas Volumetric Flowrate	m ³ /sec	Not Applicable	58.1	65.2	57.5		
Dry Gas Density	kg/m ³	Not Applicable	1.3	1.4	1.3		
Molecular Weight of Stack Gases	g/g mole	Not Applicable	30.1	30.2	30.0		
Moisture content	%	Not Applicable	22.8	18.8	17.7		
Concentration of carbon dioxide	%	Not Applicable	10.7	11.1	9.7		
Total Solid Particles	mg/m ³	100.0	15.6	41.1	24.9		
Sulphuric Acid Mist & Sulphur Trioxide as SO ₃	mg/m ³	12.0	7.0	3.5	1.8		
Nitrogen Oxides (NO _x)	mg/m ³	500.0	325.0	300.0	146.0		

Sampling Point: **Monitoring Point 3 - Ambient Air Monitoring**
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Particulates - Deposited Matter
 Monitoring Frequency Continuous with sample results extrapolated from sample period of 30 ± 2 days
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
5-Jan-21	29-Jan-21	25-Jan-21	1.64	
4-Feb-21	12-Feb-21	26-Feb-21	0.41	
5-Mar-21	12-Mar-21	8-Apr-21	0.73	
7-Apr-21	16-Apr-21	22-Apr-21	0.84	

Sampling Point: **Monitoring Point 3 - Ambient Air Monitoring**
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored PM10
 Monitoring Frequency Sampling for 24 hours every 6 Days when site is operating
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (ug/m ³)	Notes
2-Jan-21	14-Jan-21	20-Jan-21	7.8	
8-Jan-21	26-Feb-21	26-Feb-21	29.4	
14-Jan-21	26-Feb-21	26-Feb-21	11.5	
20-Jan-21	26-Feb-21	26-Feb-21	11.6	
26-Jan-21	26-Feb-21	26-Feb-21	25.9	
1-Feb-21	15-Mar-21	8-Apr-21	17.9	Sample paper went two cycles
7-Feb-21	15-Mar-21	8-Apr-21	17.9	
13-Feb-21	15-Mar-21	8-Apr-21	13.4	
19-Feb-21	15-Mar-21	8-Apr-21	20.1	
25-Feb-21	15-Mar-21	8-Apr-21	20.1	Sample paper went two cycles
3-Mar-21	20-Apr-21	22-Apr-21	23.8	
9-Mar-21	20-Apr-21	22-Apr-21	9.5	
15-Mar-21	20-Apr-21	22-Apr-21	10.3	Sample paper went two cycles
21-Mar-21	20-Apr-21	22-Apr-21	10.3	
27-Mar-21	20-Apr-21	22-Apr-21	13.4	
2-Apr-21	20-Apr-21	22-Apr-21	14.6	

Sampling Point: Monitoring Point 4 - Ambient Air Monitoring

Licencee Cape Byron Management Pty Ltd
Location Broadwater Cogeneration Power Plant
EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
Parameter Particulates - Deposited Matter
Frequency Continous with sample results extrapolated
from sample period of 30 ± 2 days
Limits Not Applicable
Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
5-Jan-21	29-Jan-21	25-Jan-21	1.28	
4-Feb-21	12-Feb-21	26-Feb-21	0.18	Spider
5-Mar-21	12-Mar-21	8-Apr-21	0.90	
7-Apr-21	16-Apr-21	22-Apr-21	0.79	

Sampling Point: Monitoring Point 5 - Ambient Air Monitoring
 Licence Cape Byron Management Pty Ltd
 Location Broadwater Power Plant Fuel Stockpile
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Particulates - Deposited Matter
 Monitoring Frequency Continuous with sample results extrapolated from sample period of 30 ± 2 days
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
5-Jan-21	29-Jan-21	25-Jan-21	1.15	
4-Feb-21	12-Feb-21	26-Feb-21	1.61	
5-Mar-21	12-Mar-21	8-Apr-21	1.85	
7-Apr-21	16-Apr-21	22-Apr-21	1.15	

Sampling Point: Monitoring Point 6 - O₂ Monitoring No 1 Cogeneration Boiler

Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Oxygen
 Monitoring Frequency Continuous Online Sampling
 Limit No Limits Prescribed



The results in the table provide a fortnightly summary of the minimum, maximum and mean daily values for the period indicated

Comments

MONITORING PERIOD		Oxygen (%)				Notes
Date Start	Date Finish	Date Published	Minimum Value	Mean Value	Maximum Value	
28-Dec-20	10-Jan-21	20-Jan-21	2.10	14.10	21.60	Boiler Online 5/01/21
11-Jan-21	24-Jan-21	29-Jan-21	2.90	7.26	21.10	
25-Jan-21	7-Feb-21	10-Feb-21	1.80	6.43	15.20	
8-Feb-21	21-Feb-21	26-Feb-21	1.40	6.94	21.20	
22-Feb-21	7-Mar-21	12-Mar-21	0.00	5.71	21.00	
8-Mar-21	21-Mar-21	8-Apr-21	1.80	8.01	21.40	
22-Mar-21	4-Apr-21	8-Apr-21	2.30	8.07	21.20	
5-Apr-21	18-Apr-21	22-Apr-21	3.20	7.34	21.30	

Sampling Point: Monitoring Point 7 - O₂ Monitoring No 12 Boiler
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.environment.nsw.gov.au/>
 Parameters Monitored Oxygen
 Monitoring Frequency Continuous Online Sampling
 Limit No Limits Prescribed



The results in the table provide a fortnightly summary of the minimum, maximum and mean daily values for the period indicated

Comments

MONITORING PERIOD			Oxygen (%)			Notes
Date Start	Date Finish	Date Published	Minimum Value	Maximum Value	Mean Value	
28-Dec-20	10-Jan-21	20-Jan-21	No Data	No Data	No Data	Boiler Not Operating
11-Jan-21	24-Jan-21	29-Jan-21	No Data	No Data	No Data	Boiler Not Operating
25-Jan-21	7-Feb-21	10-Feb-21	No Data	No Data	No Data	Boiler Not Operating
8-Feb-21	21-Feb-21	26-Feb-21	No Data	No Data	No Data	Boiler Not Operating
22-Feb-21	7-Mar-21	12-Mar-21	No Data	No Data	No Data	Boiler Not Operating
8-Mar-21	21-Mar-21	8-Apr-21	No Data	No Data	No Data	Boiler Not Operating
22-Mar-21	4-Apr-21	8-Apr-21	No Data	No Data	No Data	Boiler Not Operating
5-Apr-21	18-Apr-21	22-Apr-21	No Data	No Data	No Data	Boiler Not Operating

Sampling Point: Monitoring Point 8 - Cogeneration Cooling Water Discharge
 Licence: Cape Byron Management Pty Ltd
 Location: Broadwater Cogeneration Power Plant
 EPL No: 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored: Temperature & Volume
 Monitoring Frequency: Continuous online
 Limits: See Table
 Comments: No result may exceed the maximum limit.



MONITORING PERIOD			Temperature (°C)			Volume (kL/day)			Notes
Date Start	Date Finish	Date Published	Limit/s	Maximum	41	Limit/s	Maximum	155520	
			Min Temp	Mean Temp	Max Temp	Minimum Daily Discharge	Mean Daily Discharge	Maximum Daily Discharge	
28-Dec-20	10-Jan-21	20-Jan-21	25	31	42.2	19482	98986	137184	Boiler Online 5/01/21, excursion on 5/01/21 due to turbine control fault for 30 minutes
11-Jan-21	24-Jan-21	29-Jan-21	23	36	39.5	124752	136148	137184	
25-Jan-21	7-Feb-21	10-Feb-21	27	36	39.6	135183	137017	137184	
8-Feb-21	21-Feb-21	26-Feb-21	24	35	39	68592	124958	137184	
22-Feb-21	7-Mar-21	12-Mar-21	24	35	39	119179	134203	137184	
8-Mar-21	21-Mar-21	8-Apr-21	22	32	37	68592	128459	137184	
22-Mar-21	4-Apr-21	8-Apr-21	21	30	36	137184	137184	137184	
5-Apr-21	18-Apr-21	22-Apr-21	21	30	34	135707	137061	137184	

Sampling Point: Monitoring Point 9 - Cogeneration Cooling Water Inlet

Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored **Temperature**
 Monitoring Frequency Continuous online (by calculation)
 Limits Not Applicable - background data only



MONITORING PERIOD			Temperature (°C)			Volume (kL/day)			Notes
Date Start	Date Finish	Date Published	Minimum Background Temperature	Mean Background Temperature	Maximum Background Temperature	Minimum Daily Intake	Mean Daily Intake	Maximum Daily Intake	
28-Dec-20	10-Jan-21	20-Jan-21	23.5	27.5	44.5	19482	98986	137184	Boiler Online 5/01/21
11-Jan-21	24-Jan-21	29-Jan-21	16.7	26.3	28.3	124752	136148	137184	
25-Jan-21	7-Feb-21	10-Feb-21	26.2	28.0	30.0	135183	137017	137184	
8-Feb-21	21-Feb-21	26-Feb-21	22.9	26.5	28.8	68592	124958	137184	
22-Feb-21	7-Mar-21	12-Mar-21	21.0	26.3	28.3	119179	134203	137184	
8-Mar-21	21-Mar-21	08-Apr-21	23.1	24.9	26.9	68592	128459	137184	
22-Mar-21	4-Apr-21	08-Apr-21	22.2	23.4	25.0	137184	137184	137184	
5-Apr-21	18-Apr-21	22-Apr-21	20.7	22.0	23.4	135707	137061	137184	

Sampling Point:
 Licencee
 Location
 EPL No
 Parameters Measured
 Frequency & Method
 Licence Limits

Monitoring Point 12 - Reverse Osmosis Sidestream
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 See Table
 Biannual Grab Sample
 Not Prescribed



Pollutants	Units	Date Sampled	Date Received	Date Published	Results	Notes
Aluminium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.695	
Ammonia	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.680	
Arsenic	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.003	
Barium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.118	
Bicarbonate	CaCO ₃ /kg	13-Apr-21	19-Apr-21	22-Apr-21	37.000	
Cadmium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.001	
Calcium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	26.286	
Chloride	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	2.206	
Chromium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.001	
Conductivity	dS/m	13-Apr-21	19-Apr-21	22-Apr-21	1.170	
Copper	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.001	
Hardness (as calcium)	CaCO ₃ /kg	13-Apr-21	19-Apr-21	22-Apr-21	142.124	
Iron	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	7.673	
Lead	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.001	
Magnesium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	18.574	
Manganese	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.154	
Mercury	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.0005	
Nickel	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.002	
Nitrate	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.016	
Nitrite	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.248	
Orthophosphate	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.027	
Potassium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	8.177	
Selenium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.002	
Silica (total)	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	23.467	
Silver	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<0.001	
Sodium	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	175.331	
Sodium Adsorption Ratio	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	6.394	
Sulfate	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	115.047	
Total Dissolved Salts	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	795.600	
Total Organic Carbon	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	21.500	
Total Suspended Solids	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	<1	
Zinc	mg/l	13-Apr-21	19-Apr-21	22-Apr-21	0.024	
pH		13-Apr-21	19-Apr-21	22-Apr-21	6.780	

Sampling Point: Monitoring Point 10 - Stockpile Sediment Pond West
 Licence Cape Byron Management Pty Ltd
 Location Broadwater Power Plant Fuel Stockpile
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameter/s Monitored See Table
 Frequency & Method Monthly Grab Sample
 Limit/s None Prescribed



PARAMETERS MEASURED

Date Sampled	Date Received	Date Published	BOD ₅ (mg/L)	TSS (mg/L)	pH	Nitrogen (mg/L)	Phosphorus (mg/L)	Notes
20-Jan-21	29-Jan-21	10-Feb-21	7.6	10.0	6.4	0.9	1.2	
26-Feb-21	11-Mar-21	12-Mar-21	22.4	154.0	6.2	1.9	0.9	
16-Mar-21	6-Apr-21	8-Apr-21	19.7	150.0	6.2	<0.1	1.4	
13-Apr-21	21-Apr-21	22-Apr-21	13.0	82.0	6.0	1.0	1.1	

Sampling Point: **Monitoring Point 11 - Stockpile Sediment Pond East**
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Power Plant Fuel Stockpile
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameter/s Monitored See Table
 Frequency & Method Monthly Grab Sample
 Limit/s None Prescribed



			PARAMETERS MEASURED					
Date Sampled	Date Received	Date Published	BOD ₅ (mg/L)	TSS (mg/L)	pH	Nitrogen (mg/L)	Phosphorus (mg/L)	Notes
20-Jan-21	29-Jan-21	10-Feb-21	9.9	8.0	7.0	1.6	0.7	
26-Feb-21	11-Mar-21	12-Mar-21	3.2	32.0	6.8	1.5	0.6	
16-Mar-21	6-Apr-21	8-Apr-21	22.9	72.0	6.9	1.3	0.8	
13-Apr-21	21-Apr-21	22-Apr-21	6.0	27.0	6.9	1.2	0.5	

Sampling Point:

Licencee
Location
EPL No
Parameter/s Monitored
Frequency & Method

Rain gauge

Cape Byron Management Pty Ltd
Broadwater Cogeneration Power Plant
20425
Rainfall
Continuous Auto Sampler



TIPPING GAUGE CONTINUOUS RAINFALL MONITORING

Period From		Period To		Daily Rain	
Date	Time	Date	Time	Total (mm)	Max Intensity (mm/min)
Thursday, 31 December 2020	9:01am	Friday, 1 January 2021	9:00am	0.8	0.2
Friday, 1 January 2021	9:01am	Saturday, 2 January 2021	9:00am	15.6	0.8
Saturday, 2 January 2021	9:01am	Sunday, 3 January 2021	9:00am	0	0
Sunday, 3 January 2021	9:01am	Monday, 4 January 2021	9:00am	1.8	0.2
Monday, 4 January 2021	9:01am	Tuesday, 5 January 2021	9:00am	0	0
Tuesday, 5 January 2021	9:01am	Wednesday, 6 January 2021	9:00am	0.6	0.2
Wednesday, 6 January 2021	9:01am	Thursday, 7 January 2021	9:00am	10.6	0.4
Thursday, 7 January 2021	9:01am	Friday, 8 January 2021	9:00am	33.2	0.8
Friday, 8 January 2021	9:01am	Saturday, 9 January 2021	9:00am	11	1
Saturday, 9 January 2021	9:01am	Sunday, 10 January 2021	9:00am	1.8	0.6
Sunday, 10 January 2021	9:01am	Monday, 11 January 2021	9:00am	2.6	0.6
Monday, 11 January 2021	9:01am	Tuesday, 12 January 2021	9:00am	0.2	0.2
Tuesday, 12 January 2021	9:01am	Wednesday, 13 January 2021	9:00am	0.6	0.2
Wednesday, 13 January 2021	9:01am	Thursday, 14 January 2021	9:00am	0.2	0.2
Thursday, 14 January 2021	9:01am	Friday, 15 January 2021	9:00am	0	0
Friday, 15 January 2021	9:01am	Saturday, 16 January 2021	9:00am	2.6	0.2
Saturday, 16 January 2021	9:01am	Sunday, 17 January 2021	9:00am	0.2	0.2
Sunday, 17 January 2021	9:01am	Monday, 18 January 2021	9:00am	0	0
Monday, 18 January 2021	9:01am	Tuesday, 19 January 2021	9:00am	20	1
Tuesday, 19 January 2021	9:01am	Wednesday, 20 January 2021	9:00am	8.2	1
Wednesday, 20 January 2021	9:01am	Thursday, 21 January 2021	9:00am	6	0.2
Thursday, 21 January 2021	9:01am	Friday, 22 January 2021	9:00am	0	0
Friday, 22 January 2021	9:01am	Saturday, 23 January 2021	9:00am	0	0
Saturday, 23 January 2021	9:01am	Sunday, 24 January 2021	9:00am	0	0
Sunday, 24 January 2021	9:01am	Monday, 25 January 2021	9:00am	0	0
Monday, 25 January 2021	9:01am	Tuesday, 26 January 2021	9:00am	0	0
Tuesday, 26 January 2021	9:01am	Wednesday, 27 January 2021	9:00am	0	0
Wednesday, 27 January 2021	9:01am	Thursday, 28 January 2021	9:00am	0	0
Thursday, 28 January 2021	9:01am	Friday, 29 January 2021	9:00am	0	0
Friday, 29 January 2021	9:01am	Saturday, 30 January 2021	9:00am	0.4	0.2
Saturday, 30 January 2021	9:01am	Sunday, 31 January 2021	9:00am	0.6	0.2
Sunday, 31 January 2021	9:01am	Monday, 1 February 2021	9:00am	2.6	0.6
Monday, 1 February 2021	9:01am	Tuesday, 2 February 2021	9:00am	0	0
Tuesday, 2 February 2021	9:01am	Wednesday, 3 February 2021	9:00am	18.2	1.6
Wednesday, 3 February 2021	9:01am	Thursday, 4 February 2021	9:00am	0	0
Thursday, 4 February 2021	9:01am	Friday, 5 February 2021	9:00am	0	0
Friday, 5 February 2021	9:01am	Saturday, 6 February 2021	9:00am	0	0
Saturday, 6 February 2021	9:01am	Sunday, 7 February 2021	9:00am	0	0
Sunday, 7 February 2021	9:01am	Monday, 8 February 2021	9:00am	4.6	0.8
Monday, 8 February 2021	9:01am	Tuesday, 9 February 2021	9:00am	0.2	0.2
Tuesday, 9 February 2021	9:01am	Wednesday, 10 February 2021	9:00am	0.8	0.2
Wednesday, 10 February 2021	9:01am	Thursday, 11 February 2021	9:00am	6.6	0.6
Thursday, 11 February 2021	9:01am	Friday, 12 February 2021	9:00am	0	0
Friday, 12 February 2021	9:01am	Saturday, 13 February 2021	9:00am	0	0
Saturday, 13 February 2021	9:01am	Sunday, 14 February 2021	9:00am	12.4	0.4
Sunday, 14 February 2021	9:01am	Monday, 15 February 2021	9:00am	7	0.4
Monday, 15 February 2021	9:01am	Tuesday, 16 February 2021	9:00am	6	0.8
Tuesday, 16 February 2021	9:01am	Wednesday, 17 February 2021	9:00am	27.2	1.4
Wednesday, 17 February 2021	9:01am	Thursday, 18 February 2021	9:00am	32.2	1
Thursday, 18 February 2021	9:01am	Friday, 19 February 2021	9:00am	3.2	0.6
Friday, 19 February 2021	9:01am	Saturday, 20 February 2021	9:00am	60.6	1.4
Saturday, 20 February 2021	9:01am	Sunday, 21 February 2021	9:00am	4.6	0.4
Sunday, 21 February 2021	9:01am	Monday, 22 February 2021	9:00am	7.2	0.2
Monday, 22 February 2021	9:01am	Tuesday, 23 February 2021	9:00am	0	0
Tuesday, 23 February 2021	9:01am	Wednesday, 24 February 2021	9:00am	21.4	1
Wednesday, 24 February 2021	9:01am	Thursday, 25 February 2021	9:00am	7.6	0.8
Thursday, 25 February 2021	9:01am	Friday, 26 February 2021	9:00am	0.6	0.2
Friday, 26 February 2021	9:01am	Saturday, 27 February 2021	9:00am	0	0
Saturday, 27 February 2021	9:01am	Sunday, 28 February 2021	9:00am	0	0
Sunday, 28 February 2021	9:01am	Monday, 1 March 2021	9:00am	0	0
Monday, 1 March 2021	9:01am	Tuesday, 2 March 2021	9:00am	2.6	0.2
Tuesday, 2 March 2021	9:01am	Wednesday, 3 March 2021	9:00am	0.8	0.2
Wednesday, 3 March 2021	9:01am	Thursday, 4 March 2021	9:00am	34.6	2.4
Thursday, 4 March 2021	9:01am	Friday, 5 March 2021	9:00am	0	0
Friday, 5 March 2021	9:01am	Saturday, 6 March 2021	9:00am	3.2	0.6
Saturday, 6 March 2021	9:01am	Sunday, 7 March 2021	9:00am	3.2	0.4
Sunday, 7 March 2021	9:01am	Monday, 8 March 2021	9:00am	0.2	0.2
Monday, 8 March 2021	9:01am	Tuesday, 9 March 2021	9:00am	21.4	1
Tuesday, 9 March 2021	9:01am	Wednesday, 10 March 2021	9:00am	1.6	0.2
Wednesday, 10 March 2021	9:01am	Thursday, 11 March 2021	9:00am	12.8	0.8
Thursday, 11 March 2021	9:01am	Friday, 12 March 2021	9:00am	38.2	1.4
Friday, 12 March 2021	9:01am	Saturday, 13 March 2021	9:00am	0	0
Saturday, 13 March 2021	9:01am	Sunday, 14 March 2021	9:00am	0	0
Sunday, 14 March 2021	9:01am	Monday, 15 March 2021	9:00am	21.8	1
Monday, 15 March 2021	9:01am	Tuesday, 16 March 2021	9:00am	5.8	0.2
Tuesday, 16 March 2021	9:01am	Wednesday, 17 March 2021	9:00am	6	0.4
Wednesday, 17 March 2021	9:01am	Thursday, 18 March 2021	9:00am	40.2	1.2
Thursday, 18 March 2021	9:01am	Friday, 19 March 2021	9:00am	10	0.4
Friday, 19 March 2021	9:01am	Saturday, 20 March 2021	9:00am	14.8	1.2
Saturday, 20 March 2021	9:01am	Sunday, 21 March 2021	9:00am	37.2	1
Sunday, 21 March 2021	9:01am	Monday, 22 March 2021	9:00am	88.6	2
Monday, 22 March 2021	9:01am	Tuesday, 23 March 2021	9:00am	40	0.6
Tuesday, 23 March 2021	9:01am	Wednesday, 24 March 2021	9:00am	31.2	0.6
Wednesday, 24 March 2021	9:01am	Thursday, 25 March 2021	9:00am	0	0
Thursday, 25 March 2021	9:01am	Friday, 26 March 2021	9:00am	0	0
Friday, 26 March 2021	9:01am	Saturday, 27 March 2021	9:00am	0	0
Saturday, 27 March 2021	9:01am	Sunday, 28 March 2021	9:00am	0	0
Sunday, 28 March 2021	9:01am	Monday, 29 March 2021	9:00am	0	0
Monday, 29 March 2021	9:01am	Tuesday, 30 March 2021	9:00am	11.4	1.2
Tuesday, 30 March 2021	9:01am	Wednesday, 31 March 2021	9:00am	0.2	0.2
Wednesday, 31 March 2021	9:01am	Thursday, 1 April 2021	9:00am	24.2	1.6
Thursday, 1 April 2021	9:01am	Friday, 2 April 2021	9:00am	25.6	0.8
Friday, 2 April 2021	9:01am	Saturday, 3 April 2021	9:00am	0	0
Saturday, 3 April 2021	9:01am	Sunday, 4 April 2021	9:00am	1	0.2
Sunday, 4 April 2021	9:01am	Monday, 5 April 2021	9:00am	19.2	0.6
Monday, 5 April 2021	9:01am	Tuesday, 6 April 2021	9:00am	28.6	0.2
Tuesday, 6 April 2021	9:01am	Wednesday, 7 April 2021	9:00am	19.2	0.6
Wednesday, 7 April 2021	9:01am	Thursday, 8 April 2021	9:00am	9.8	0.8
Thursday, 8 April 2021	9:01am	Friday, 9 April 2021	9:00am	3.8	0.2

Sampling Point:

Licencee
 Location
 EPL No
 Parameter/s Monitored
 Frequency & Method

Rain gauge

Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425
 Rainfall
 Continuous Auto Sampler

**TIPPING GUAGE CONTINUOUS RAINFALL MONITORING**

Period From		Period To		Daily Rain	
Date	Time	Date	Time	Total (mm)	Max Intensity (mm/min)
Friday, 9 April 2021	9:01am	Saturday, 10 April 2021	9:00am	0	0
Saturday, 10 April 2021	9:01am	Sunday, 11 April 2021	9:00am	0	0
Sunday, 11 April 2021	9:01am	Monday, 12 April 2021	9:00am	2	0.2
Monday, 12 April 2021	9:01am	Tuesday, 13 April 2021	9:00am	0.2	0.2
Tuesday, 13 April 2021	9:01am	Wednesday, 14 April 2021	9:00am	0	0
Wednesday, 14 April 2021	9:01am	Thursday, 15 April 2021	9:00am	0	0
Thursday, 15 April 2021	9:01am	Friday, 16 April 2021	9:00am	0	0
Friday, 16 April 2021	9:01am	Saturday, 17 April 2021	9:00am	0	0
Saturday, 17 April 2021	9:01am	Sunday, 18 April 2021	9:00am	4.6	0.2
Sunday, 18 April 2021	9:01am	Monday, 19 April 2021	9:00am	0	0
Monday, 19 April 2021	9:01am	Tuesday, 20 April 2021	9:00am	0	0
Tuesday, 20 April 2021	9:01am	Wednesday, 21 April 2021	9:00am	0	0

Licencee Cape Byron Management Pty Ltd
Location Broadwater Cogeneration Power Plant
EPL No 20425



CORRECTIONS LOG

Date Sampled	Monitoring Point	Pollutant/Parameter	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason