



Environmental Monitoring Report V2

Broadwater Power Plant 117 Baraang Drive Broadwater NSW

Licencee Cape Byron Management Pty Ltd
Address 117 Baraang Drive Broadwater NSW
EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>

This data is published as required under section 66(6) of the *Protection of the Environment Operations Act 1997*

Sampling Point:

Licencee

Location

EPL No

Parameters Monitored

Frequency & Method

Limits

Monitoring Point 1 - No 12 Boiler Stack Emissions

Cape Byron Management Pty Ltd

Broadwater Cogeneration Power Plant

20425 <http://www.epa.nsw.gov.au/prpoeoapp/>

see individual parameters in table

Annually in accordance with EPA protocols

see individual parameters in table



			RESULTS TABLE			
			AE 13192	AE 13741	AE 14703	AE 15185
Report Number			16-Jul-20	15-Jul-21	15-Dec-22	13-Sep-23
Sampling Date			25-Aug-20	02-Aug-21	11-Jan-23	06-Oct-23
Date Received			27-Aug-20	13-Aug-21	25-Jan-23	07-Feb-24
Date Published						
Measured Parameters dry @ STP and corrected to 7% O ₂	Units	Concentration Limit				
Average stack gas temperature	°C	Not Applicable	108.0	88.0	98.0	80.0
Average velocity at sampling plane	m/s	Not Applicable	8.1	9.7	6.6	10.0
Gas Volumetric Flowrate	m ³ /sec	Not Applicable	20.9	47.8	20.5	64.0
Dry Gas Density	kg/m ³	Not Applicable	1.3	1.3	1.2	1.3
Molecular Weight of Stack Gases	g/g mole	Not Applicable	30.1	30.1	29.9	29.4
Moisture content	%	Not Applicable	26.7	20.1	13.1	18.3
Concentration of carbon dioxide	mg Drive Broadw	Not Applicable	10.6	11.0	9.3	4.5
Total Solid Particles	mg/m ³	100	70.7	42.7	61.0	75.0
Sulphuric Acid Mist & Sulphur Trioxide as SO ₃	mg/m ³	12	5.6	11.3	10.9	10.9
Nitrogen Oxides (NO _x)	mg/m ³	500	368.0	270.0	266.0	442.0

117 Baraang Drive Broadwater NSW

Sampling Point:

Licencee
 Location
 EPL No
 Parameter/s Monitored
 Frequency & Method
 Limits

Monitoring Point 2 - No 1 Cogeneration Boiler Stack Emissions

Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 see individual parameters in table
 Quarterly in accordance with EPA protocols
 see individual parameters in table



RESULTS TABLE										
Report Number	AE 14555 AE 14703 AE 14762 AE 14903 AE 15072 AE 15185 AE15397 AE15490									
Sampling Date	16-Sep-22 15-Dec-22 09-Feb-23 19-Apr-23 11-Jul-23 23-Nov-23 17-Jan-24 07-Mar-24									
Date Received	03-Nov-22 11-Jan-23 20-Mar-23 05-May-23 14-Aug-23 29-Jan-24 11-Feb-24 16-Apr-24									
Date Published	25-Jan-23 25-Jan-23 22-Mar-23 17-May-23 23-Aug-23 07-Feb-24 21-Feb-24 17-Apr-24									
Measured Parameters dry @ STP and corrected to 7% O ₂	Units	Concentration Limit								
Average stack gas temperature	°C	Not Applicable	73.3	64.0	64.0	63.0	70.0	64.0	63.7	60.0
Average velocity at sampling plane	m/s	Not Applicable	16.7	15.1	23.9	16.5	16.9	8.1	20.1	14.8
Dry Gas Volumetric Flowrate	Nm ³ /sec	Not Applicable	67.0	61.7	103.6	67.7	67.7	68.4	85.1	64.4
Dry Gas Density	kg/Nm ³	Not Applicable	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
Molecular Weight of Stack Gases	g/g mole	Not Applicable	28.8	30.1	30.0	29.9	30.0	29.9	29.8	29.8
Moisture content	%	Not Applicable	19.9	19.5	15.2	20.3	20.9	12.8	17.3	16.4
Concentration of carbon dioxide	%	Not Applicable	12.7	10.5	9.7	9.2	10.0	8.8	8.3	7.8
Total Solid Particles	mg/Nm ³	100	21.5	19.2	17.1	17.6	64.7	30.6	29.0	44.2
Sulphuric Acid Mist & Sulphur Trioxide as SO ₃	mg/Nm ³	12	0.9	11.9	11.97	11.96	7.00	5.50	7.90	1.80
Nitrogen Oxides (NO _x)	mg/Nm ³	500	247.0	279.0	136.0	171.0	299.0	229.0	172.0	215.0

Sampling Point: Monitoring Point 3 - Ambient Air Monitoring
 Licence Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored PM10
 Monitoring Frequency Sampling for 24 hours every 6 Days when site is operating
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (ug/m ³)	Notes
12-Dec-23	19-Jan-24	24-Jan-24	24.9	
18-Dec-23	19-Jan-24	24-Jan-24	19.7	
24-Dec-23	19-Jan-24	24-Jan-24	7.5	
30-Dec-23	19-Jan-24	24-Jan-24	13.6	
5-Jan-24	19-Jan-24	24-Jan-24	11.8	
11-Jan-24	15-Feb-24	21-Feb-24	20.6	
17-Jan-24	15-Feb-24	21-Feb-24	12.1	
23-Jan-24	15-Feb-24	21-Feb-24	21.5	
29-Jan-24	15-Feb-24	21-Feb-24	22.9	
4-Feb-24	15-Mar-24	20-Mar-24	N/A	paper lost in transit
10-Feb-24	15-Mar-24	20-Mar-24	16.5	
16-Feb-24	15-Mar-24	20-Mar-24	11.0	
22-Feb-24	15-Mar-24	20-Mar-24	11.8	
28-Feb-24	15-Mar-24	20-Mar-24	16.4	
5-Mar-24	18-Apr-24	1-May-24	13.6	
11-Mar-24	18-Apr-24	1-May-24	16.6	
17-Mar-24	18-Apr-24	1-May-24	4.9	
23-Mar-24	18-Apr-24	1-May-24	11.7	
29-Mar-24	18-Apr-24	1-May-24	7.8	
4-Apr-24	10-May-24	15-May-24	8.1	
10-Apr-24	10-May-24	15-May-24	9.4	
16-Apr-24	10-May-24	15-May-24	10.7	
22-Apr-24	10-May-24	15-May-24	6.5	
4-May-24	17-May-24	12-Jun-24	14.8	
10-May-24	17-May-24	12-Jun-24	7.8	
16-May-24	17-May-24	12-Jun-24	6.0	
22-May-24	17-May-24	12-Jun-24	5.7	
28-May-24	17-May-24	12-Jun-24	8.2	
3-Jun-24	11-Jul-24	24-Jul-24	3.4	
9-Jun-24	11-Jul-24	24-Jul-24	6.1	
15-Jun-24	11-Jul-24	24-Jul-24	5.0	
21-Jun-24	11-Jul-24	24-Jul-24	15.4	
27-Jun-24	11-Jul-24	24-Jul-24	15.0	
3-Jul-24	7-Aug-24	21-Aug-24	6.4	
9-Jul-24	7-Aug-24	21-Aug-24	7.1	
15-Jul-24	7-Aug-24	21-Aug-24	7.4	
21-Jul-24	7-Aug-24	21-Aug-24	10.6	
27-Jul-24	7-Aug-24	21-Aug-24	14.4	

Sampling Point: **Monitoring Point 3 - Ambient Air Monitoring**
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Particulates - Deposited Matter
 Monitoring Frequency Continous with sample results extrapolated from sample period of 30 ± 2 days
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
5-Aug-02	11-Aug-21	13-Aug-21	0.77	
7-Sep-21	10-Sep-21	23-Sep-21	1.64	Large org. matter
7-Oct-21	19-Oct-21	22-Oct-21	0.80	Fine org. matter
7-Dec-21	15-Dec-21	15-Dec-21	2.20	Bug, large org. matter
1-Jan-22	21-Jan-22	28-Jan-22	1.54	Fine org. matter
1-Feb-22	NR	28-Feb-22	N/A	Bottles flooded
1-Mar-22	NR	31-Mar-22	N/A	Bottles flood damaged and not serviceable, new bottles set 20/04/2022
1-Apr-22	NR	30-Apr-22	N/A	New bottles placed on 20/4/22
5-May-22	11-May-22	1-Jun-22	0.13	
6-Jun-22	20-Jun-22	29-Jun-22	4.30	
5-Jul-22	8-Jul-22	27-Jul-22	0.19	
4-Aug-22	9-Aug-22	24-Aug-22	0.16	
5-Sep-22	12-Sep-22	21-Sep-22	0.41	
5-Oct-22	6-Oct-22	2-Nov-22	0.32	
7-Nov-22	11-Nov-22	30-Nov-22	0.20	
5-Dec-22	20-Dec-22	28-Dec-22	0.73	
9-Jan-23	12-Jan-23	11-Jan-23	0.63	
6-Feb-23	10-Feb-23	22-Feb-23	0.32	
6-Mar-23	9-Feb-23	22-Mar-23	0.73	
3-Apr-23	14-Apr-23	3-May-23	0.34	
8-May-23	12-May-23	31-May-23	0.28	
13-Jun-23	19-Jun-23	28-Jun-23	0.02	36 days exposure due to delivery delays
10-Jul-23	17-Jul-23	26-Jul-23	0.50	
7-Aug-23	15-Aug-23	23-Aug-23	0.66	
5-Sep-23	11-Sep-23	5-Oct-23	0.33	
4-Oct-23	19-Oct-23	1-Nov-23	1.08	
6-Nov-23	14-Nov-23	16-Nov-23	6.91	
5-Dec-23	13-Dec-23	10-Jan-24	0.67	
8-Jan-24	12-Jan-24	24-Jan-24	0.32	
5-Feb-24	9-Feb-24	21-Feb-24	0.15	
4-Mar-24	8-Mar-24	20-Mar-24	0.28	
8-Apr-24	12-Mar-24	17-Apr-24	0.59	
6-May-24	15-May-24	29-May-24	0.13	
5-Jun-24	14-Jun-24	26-Jun-24	0.28	
8-Jul-24	12-Jul-24	24-Jul-24	0.17	
5-Aug-24	8-Aug-24	21-Aug-24	0.36	

Sampling Point: Monitoring Point 4 - Ambient Air Monitoring

Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameter Particulates - Deposited Matter
 Frequency Continous with sample results extrapolated from sample period of 30 ± 2 days
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
2-Jul-21	9-Jul-21	16-Jul-21	0.97	Fine org. matter
5-Aug-21	11-Aug-21	13-Aug-21	1.02	
7-Sep-21	10-Sep-21	23-Sep-21	1.49	Large org. matter
7-Oct-21	19-Oct-21	22-Oct-21	1.01	Fine org. matter
7-Dec-21	15-Dec-21	15-Dec-21	0.59	Dirt, large org. matter
1-Jan-22	21-Jan-22	28-Jan-22	1.11	
01-Feb-22	NR	NR	N/A	Bottles flooded
01-Mar-22	NR	NR	N/A	Bottles flood damaged and not serviceable, new bottles set 20/04/2022
1-Apr-22	NR	30-Apr-22	N/A	New bottles placed on 20/4/22
5-May-22	11-May-22	1-Jun-22	0.23	
6-Jun-22	20-Jun-22	29-Jun-22	4.80	
5-Jul-22	8-Jul-22	27-Jul-22	0.33	
4-Aug-22	9-Aug-22	24-Aug-22	0.25	
5-Sep-22	12-Sep-22	21-Sep-22	0.41	
5-Oct-22	6-Oct-22	2-Nov-22	0.86	
7-Nov-22	11-Nov-22	30-Nov-22	0.11	
5-Dec-22	20-Dec-22	28-Dec-22	0.61	
9-Jan-23	12-Jan-23	11-Jan-23	0.51	
6-Feb-23	10-Feb-23	22-Feb-23	0.71	
6-Mar-23	9-Mar-23	22-Mar-23	1.49	
3-Apr-23	14-Apr-23	3-May-23	0.36	
8-May-23	12-May-23	31-May-23	0.55	
13-Jun-23	19-Jun-23	28-Jun-23	0.13	36 days exposure due to delivery delays
10-Jul-23	17-Jul-23	26-Jul-23	0.85	
7-Aug-23	15-Aug-23	23-Aug-23	1.24	
5-Sep-23	11-Sep-23	5-Oct-23	0.90	
4-Oct-23	19-Oct-23	1-Nov-23	4.20	
6-Nov-23	14-Nov-23	16-Nov-23	9.89	
5-Dec-23	13-Dec-23	10-Jan-24	0.54	
8-Jan-24	12-Jan-24	24-Jan-24	1.06	
5-Feb-24	9-Feb-24	21-Feb-24	0.16	
4-Mar-24	8-Mar-24	20-Mar-24	0.48	
8-Apr-24	12-Mar-24	17-Apr-24	0.51	
6-May-24	15-May-24	29-May-24	0.27	
5-Jun-24	14-Jun-24	26-Jun-24	0.25	
8-Jul-24	12-Jul-24	24-Jul-24	0.43	
5-Aug-24	8-Aug-24	21-Aug-24	1.00	

Sampling Point: Monitoring Point 5 - Ambient Air Monitoring
 Licence Cape Byron Management Pty Ltd
 Location Broadwater Power Plant Fuel Stockpile
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Particulates - Deposited Matter
 Monitoring Frequency Continuous with sample results extrapolated from sample period of 30 ± 2 days
 Limits Not Applicable
 Comments Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
1-Apr-22	NR	30-Apr-22	N/A	New bottles placed on 20/4/22
5-May-22	11-May-22	1-Jun-22	0.17	
6-Jun-22	20-Jun-22	29-Jun-22	5.00	
5-Jul-22	8-Jul-22	27-Jul-22	0.65	
4-Aug-22	9-Aug-22	24-Aug-22	0.08	
5-Sep-22	12-Sep-22	21-Sep-22	0.56	
5-Oct-22	6-Oct-22	2-Nov-22	1.33	
7-Nov-22	11-Nov-22	30-Nov-22	1.14	
5-Dec-22	20-Dec-22	28-Dec-22	1.50	
9-Jan-23	12-Jan-23	11-Jan-23	4.02	
6-Feb-23	10-Feb-23	22-Feb-23	1.62	
6-Mar-23	9-Feb-23	22-Mar-23	5.21	
3-Apr-23	14-Apr-23	3-May-23	1.23	
8-May-23	12-May-23	31-May-23	1.00	
13-Jun-23	19-Jun-23	28-Jun-23	0.02	36 days exposure due to delivery delays
10-Jul-23	17-Jul-23	26-Jul-23	0.81	
7-Aug-23	15-Aug-23	23-Aug-23	0.92	
5-Sep-23	11-Sep-23	5-Oct-23	0.36	
4-Oct-23	19-Oct-23	1-Nov-23	1.64	
6-Nov-23	14-Nov-23	16-Nov-23	7.18	
5-Dec-23	13-Dec-23	10-Jan-24	1.77	
8-Jan-24	12-Jan-24	24-Jan-24	1.10	
5-Feb-24	9-Feb-24	21-Feb-24	0.60	
4-Mar-24	8-Mar-24	20-Mar-24	0.44	
8-Apr-24	12-Mar-24	17-Apr-24	0.71	
6-May-24	15-May-24	29-May-24	0.23	
5-Jun-24	14-Jun-24	26-Jun-24	0.58	
8-Jul-24	12-Jul-24	24-Jul-24	0.33	
5-Aug-24	8-Aug-24	21-Aug-24	0.62	

Sampling Point: Monitoring Point 7 - O₂ Monitoring No 12 Boiler
 Licence: Cape Byron Management Pty Ltd
 Location: Broadwater Cogeneration Power Plant
 EPL No: 20425 <http://www.environment.nsw.gov.au/>
 Parameters Monitored: Oxygen
 Monitoring Frequency: Continuous Online Sampling
 Limit: No Limits Prescribed
 The results in the table provide a fortnightly summary of the minimum, maximum and mean daily values for the period indicated



Comments

MONITORING PERIOD			Oxygen (%)			Notes
Date Start	Date Finish	Date Published	Minimum Value	Maximum Value	Mean Value	
9-Jan-23	22-Jan-23	23-Jan-23	0.89	21.0	8.70	
23-Jan-23	5-Feb-23	8-Feb-23	1.86	20.6	19.59	Boiler offline 23/1/23
26-Jun-23	9-Jul-23	9-Aug-23	0.02	21.0	20.07	Boiler start-up 4/7/23; boiler offline 4/7/23, 5/7/23, 6/7/23, 7/7/23
10-Jul-23	23-Jul-23	9-Aug-23	0.02	21.0	12.37	Boiler offline 10/7/23 - 22/7/23
24-Jul-23	6-Aug-23	9-Aug-23	0.02	21.0	12.36	Boiler offline 5/8/23 - 8/8/23
7-Aug-23	20-Aug-23	23-Aug-23	0.02	21.0	14.12	Boiler offline 11/8/23 - 15/8/23, 20/8/23
21-Aug-23	3-Sep-23	6-Sep-23	0.02	21.0	13.71	Boiler offline 25/8/23 - 27/8/23, 2/8/23 - 4/8/23
4-Sep-23	17-Sep-23	20-Sep-23	0.00	21.0	14.71	Boiler offline 9/9/23 - 11/9/23, 15/9/23 - 17/9/23
18-Sep-23	1-Oct-23	5-Oct-23	0.00	21.0	13.87	Boiler offline 23/9/23 - 24/9/23, 30/9/23 - 2/10/23
2-Oct-23	15-Oct-23	18-Oct-23	0.02	21.0	17.63	Boiler offline 2/10/23, 7/10/23, 8/10/23, 14/10/23, 15/10/23
16-Oct-23	29-Oct-23	1-Nov-23	0.02	21.0	15.30	Boiler offline 19/10/23 - 23/10/23, 27/10/23 - 31/10/23
30-Oct-23	12-Nov-23	16-Nov-23	0.31	21.0	19.82	Boiler offline 1/11/23 - 16/11/23
24-Jun-24	7-Jul-24	10-Jul-24	0.00	21.0	15.98	Boiler offline 29/6-30/6, 6/7-8/7
8-Jul-24	21-Jul-24	24-Jul-24	0.00	21.0	17.84	Boiler offline 9/7-16/7, 20/7
22-Jul-24	4-Aug-24	7-Aug-24	0.24	21.0	12.85	Boiler offline 26/7-29/7
5-Aug-24	18-Aug-24	21-Aug-24	0.02	21.0	16.10	Boiler offline 13/8-18/8

Sampling Point: Monitoring Point 6 - O₂ Monitoring No 1 Cogeneration Boiler
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Oxygen
 Monitoring Frequency Continuous Online Sampling
 Limit No Limits Prescribed
 The results in the table provide a fortnightly summary of the minimum, maximum and mean daily values for the period indicated



Comments

MONITORING PERIOD		Oxygen (%)				Notes
Date Start	Date Finish	Date Published	Minimum Value	Mean Value	Maximum Value	
10-Jul-23	23-Jul-23	26-Jul-23	0.20	3.93	20.9	Boiler offline 22/7/23
24-Jul-23	6-Aug-23	9-Aug-23	0.00	5.89	21.3	Boiler offline 30/7/23, 31/7/23, 5/8/23, 6/8/23
7-Aug-23	20-Aug-23	23-Aug-23	0.00	7.28	21.3	Boiler offline 7/8/23, 12/8/23, 13/8/23, 19/8/23, 20/8/23
21-Aug-23	3-Sep-23	6-Sep-23	0.00	6.62	21.3	Boiler offline 21/8/23, 26/8/23, 27/8/23, 3/9/23
4-Sep-23	17-Sep-23	20-Sep-23	0.00	4.99	21.2	Boiler offline 10/9/23, 11/9/23, 17/9/23
18-Sep-23	1-Oct-23	5-Oct-23	0.00	4.98	21.2	Boiler offline 28/9/23, 1/10/23
2-Oct-23	15-Oct-23	18-Oct-23	0.20	7.53	21.3	Boiler offline 2/10/23, 7/10/23, 8/10/23, 14/10/23, 15/10/23
16-Oct-23	29-Oct-23	1-Nov-23	0.00	7.32	21.3	Boiler offline 19/10/23 - 22/10/23, 28/10/23, 29/10/23
30-Oct-23	12-Nov-23	16-Nov-23	0.10	7.73	21.2	Boiler offline 4/11/23, 5/11/23, 7/11/23, 12/11/23
13-Nov-23	26-Nov-23	30-Nov-23	0.00	11.69	21.5	Boiler offline 13/11/23 - 17/11/23, 20/11/23, 25/11/23
27-Nov-23	10-Dec-23	13-Dec-23	0.00	8.81	21.3	Boiler offline 1/12/23 - 4/12/23
11-Dec-23	24-Dec-23	27-Dec-23	2.10	11.12	21.5	Boiler offline 21/12/23
25-Dec-23	7-Jan-24	10-Jan-24	1.00	16.77	21.8	Boiler offline 25/12/23 - 2/1/24, 5/1/24 - 7/1/24
8-Jan-24	21-Jan-24	24-Jan-24	3.00	8.75	21.2	Boiler offline 8/1/24, 12/1/24 - 14/1/24, 19/1/24 - 21/1/24
22-Jan-24	4-Feb-24	7-Feb-24	3.30	11.59	21.3	Boiler offline 22/1, 26/1-29/1, 31/1-4/2
5-Feb-24	18-Feb-24	21-Feb-24	2.30	8.76	21.2	Boiler offline 9/2 - 12/2, 16/2 - 18/2
19-Feb-24	3-Mar-24	6-Mar-24	1.40	9.43	21.4	Boiler offline 19/2, 23/2-27/2, 2/3-3/3
4-Mar-24	17-Mar-24	20-Mar-24	2.90	8.65	21.2	Boiler offline 4/3, 9/3-11/3, 15/3-17/3
18-Mar-24	31-Mar-24	3-Apr-24	2.00	11.18	21.2	Boiler offline 18/3, 19/3, 23/3 - 25/3, 28/3 - 31/3
1-Apr-24	14-Apr-24	17-Apr-24	0.00	21.35	21.6	Plant shutdown from 28/3 - 15/4
15-Apr-24	28-Apr-24	1-May-24	2.50	6.08	21.5	Boiler offline 15/4, 27/4, 28/4
29-Apr-24	12-May-24	15-May-24	0.60	10.68	21.3	Boiler offline 29/4, 2/5, 3/5-6/5, 8/5-12/5
13-May-24	26-May-24	29-May-24	3.00	13.46	21.3	Boiler offline on weekends
27-May-24	9-Jun-24	12-Jun-24	2.90	11.06	21.7	Boiler offline 27/5, 30/5-4/6, 6/6-9/6
10-Jun-24	23-Jun-24	26-Jun-24	3.00	11.99	21.4	Boiler offline 10/6, 11/6, 14/6-18/6, 22/6, 23/6
24-Jun-24	7-Jul-24	10-Jul-24	0.60	4.63	21.3	Boiler offline 24/6, 30/6, 6/7-7/7
8-Jul-24	21-Jul-24	24-Jul-24	0.00	1.21	21.3	Boiler offline 8/7, 9/7 & 21/7
22-Jul-24	4-Aug-24	7-Aug-24	0.00	5.99	21.3	Boiler offline 22/7, 26/7-28/7
5-Aug-24	18-Aug-24	21-Aug-24	0.00	4.64	21.2	Boiler offline 9/8, 17/8-18/8

Sampling Point: Monitoring Point 8 - Cogeneration Cooling Water Discharge
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Temperature & Volume
 Monitoring Frequency Continuous online
 Limits See Table
 Comments No result may exceed the maximum limit.



MONITORING PERIOD			Temperature (°C)			Volume (kL/day)			Notes
			Limit/s	Maximum	41	Limit/s	Maximum	155520	
Date Start	Date Finish	Date Published	Min Temp	Mean Temp	Max Temp	Minimum Daily Discharge	Mean Daily Discharge	Maximum Daily Discharge	
30-Oct-23	12-Nov-23	16-Nov-23	23	33	39	97934	130619	137184	Boiler offline 4/11/23, 5/11/23, 7/11/23, 12/11/23
13-Nov-23	26-Nov-23	30-Nov-23	24	31	37	8955	112531	137184	Boiler offline 13/11/23 - 17/11/23, 20/11/23, 25/11/23
27-Nov-23	10-Dec-23	13-Dec-23	26	35	45	68592	123513	137184	Boiler offline 1/12/23 - 4/12/23, temperature spike due to factory offline 01/12 - 12:34 water in pipe exposed to sun
11-Dec-23	24-Dec-23	27-Dec-23	27	34	40	98220	125865	137184	Boiler offline 21/12/23
25-Dec-23	7-Jan-24	10-Jan-24	24	30	38	67782	89135	137184	Boiler offline 25/12/23 - 2/1/24, 5/1/24 - 7/1/24
8-Jan-24	21-Jan-24	24-Jan-24	25	34	40	68592	125397	137184	Boiler offline 8/1/24, 12/1/24 - 14/1/24, 19/1/24 - 21/1/24
22-Jan-24	4-Feb-24	7-Feb-24	22	33	40	54064	114887	137184	Boiler offline 22/1, 26/1-29/1, 31/1-4/2
5-Feb-24	18-Feb-24	21-Feb-24	26	36	41	137184	137184	137184	
19-Feb-24	3-Mar-24	6-Mar-24	27	35	41	68592	124258	137184	Boiler offline 19/2, 23/2-27/2, 2/3-3/3
4-Mar-24	17-Mar-24	20-Mar-24	26	35	40	68592	122167	137184	Boiler offline 4/3, 9/3-11/3, 15/3-17/3
18-Mar-24	31-Mar-24	3-Apr-24	24	31	37	68592	119876	137184	Boiler offline 18/3, 19/3, 23/3 - 25/3, 28/3 - 31/3
1-Apr-24	14-Apr-24	17-Apr-24	23	25	26	0	0	0	Plant shutdown from 28/3 - 15/4
15-Apr-24	28-Apr-24	1-May-24	23	31	35	136327	137106	137184	Boiler offline 15/4, 27/4, 28/4
29-Apr-24	12-May-24	15-May-24	20	27	32	68592	115416	137184	Boiler offline 29/4, 2/5, 3/5-6/5, 8/5-12/5
13-May-24	26-May-24	29-May-24	17	23	34	68592	111575	137184	Boiler offline on weekends
27-May-24	9-Jun-24	12-Jun-24	17	24	30	68592	116771	137184	Boiler offline 27/5, 30/5-4/6, 6/6-9/6
10-Jun-24	23-Jun-24	26-Jun-24	16	22	30	68592	105781	137184	Boiler offline 10/6, 11/6, 14/6- 18/6, 22/6, 23/6
24-Jun-24	7-Jul-24	10-Jul-24	16	24	30	129896	135972	137184	Boiler offline 24/6, 30/6, 6/7-7/7
8-Jul-24	21-Jul-24	24-Jul-24	15	23	30	74784	125367	137184	Boiler offline 8/7, 9/7 & 21/7
22-Jul-24	4-Aug-24	7-Aug-24	15	23	29	101316	132122	137184	Boiler offline 22/7, 26/7-28/7
5-Aug-24	18-Aug-24	21-Aug-24	17	24	29	136755	137145	137184	Boiler offline 9/8, 17/8-18/8

Sampling Point: Monitoring Point 9 - Cogeneration Cooling Water Inlet

Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameters Monitored Temperature
 Monitoring Frequency Continuous online (by calculation)
 Limits Not Applicable - background data only



MONITORING PERIOD			Temperature (°C)			Volume (kL/day)			Notes
Date Start	Date Finish	Date Published	Minimum Background Temperature	Mean Background Temperature	Maximum Background Temperature	Minimum Daily Intake	Mean Daily Intake	Maximum Daily Intake	
24-Jul-23	6-Aug-23	9-Aug-23	17.5	19.0	20.6	106842	133417	137184	Boiler offline 30/7/23, 31/7/23, 5/8/23, 6/8/23
7-Aug-23	20-Aug-23	23-Aug-23	18.3	20.2	21.7	80310	127856	137184	Boiler offline 7/8/23, 12/8/23, 13/8/23, 19/8/23, 20/8/23
21-Aug-23	3-Sep-23	6-Sep-23	19.4	20.8	22.4	83501	127018	137184	Boiler offline 21/8/23, 26/8/23, 27/8/23, 3/9/23
4-Sep-23	17-Sep-23	20-Sep-23	14.6	22.3	23.9	117988	135426	137184	Boiler offline 10/9/23, 11/9/23, 17/9/23
18-Sep-23	1-Oct-23	5-Oct-23	22.0	23.2	24.7	128086	136235	137184	Boiler offline 28/9/23, 1/10/23
2-Oct-23	15-Oct-23	18-Oct-23	22.9	24.3	26.1	101126	134076	137184	Boiler offline 2/10/23, 7/10/23, 8/10/23, 14/10/23, 15/10/23
16-Oct-23	29-Oct-23	1-Nov-23	23.6	25.1	27.5	95314	131694	137184	Boiler offline 19/10/23 - 22/10/23, 28/10/23, 29/10/23
30-Oct-23	12-Nov-23	16-Nov-23	21.8	24.7	25.9	97934	130619	137184	Boiler offline 4/11/23, 5/11/23, 7/11/23, 12/11/23
13-Nov-23	26-Nov-23	30-Nov-23	20.2	27.4	39.9	8955	112531	137184	Boiler offline 13/11/23 - 17/11/23, 20/11/23 - high temp due to plant shutdown with water sitting in pipe exposed to sun
27-Nov-23	10-Dec-23	13-Dec-23	26.5	28.4	36.3	68592	123513	137184	Boiler offline 1/12/23 - 4/12/23.
11-Dec-23	24-Dec-23	27-Dec-23	27.8	29.6	39.4	98220	125865	137184	Boiler offline 21/12/23
25-Dec-23	7-Jan-24	10-Jan-24	23.8	28.2	30.9	67782	89135	137184	Boiler offline 25/12/23 - 2/1/24, 5/1/24 - 7/1/24
8-Jan-24	21-Jan-24	24-Jan-24	25.3	27.7	29.2	68592	125397	137184	Boiler offline 8/1/24, 12/1/24 - 14/1/24, 19/1/24 - 21/1/24
22-Jan-24	4-Feb-24	7-Feb-24	22.0	29.3	39.3	54064	114887	137184	Boiler offline 22/1, 26/1-29/1, 31/1-4/2.
5-Feb-24	18-Feb-24	21-Feb-24	27.2	29.6	31.2	137184	137184	137184	
19-Feb-24	3-Mar-24	6-Mar-24	27.9	29.2	30.2	68592	124258	137184	Boiler offline 19/2, 23/2-27/2, 2/3-3/3
4-Mar-24	17-Mar-24	20-Mar-24	27.0	28.2	29.8	68592	122167	137184	Boiler offline 4/3, 9/3-11/3, 15/3-17/3
18-Mar-24	31-Mar-24	3-Apr-24	22.5	26.6	28.4	68592	119876	137184	Boiler offline 18/3, 19/3, 23/3 - 25/3, 28/3 - 31/3
1-Apr-24	14-Apr-24	17-Apr-24	18.1	26.7	43.1	0	0	0	Plant shutdown from 28/3 - 15/4
15-Apr-24	28-Apr-24	1-May-24	21.4	23.7	25.8	136327	137106	137184	Boiler offline 15/4, 27/4, 28/4
29-Apr-24	12-May-24	15-May-24	20.9	21.8	22.9	68592	115416	137184	Boiler offline 29/4, 2/5, 3/5-6/5, 8/5-12/5
13-May-24	26-May-24	29-May-24	18.2	19.9	21.4	68592	111575	137184	Boiler offline on weekends
27-May-24	9-Jun-24	12-Jun-24	18.3	19.2	20.1	68592	116771	137184	Boiler offline 27/5, 30/5-4/6, 6/6-9/6
10-Jun-24	23-Jun-24	26-Jun-24	17.2	17.9	18.8	68592	105781	137184	Boiler offline 10/6, 11/6, 14/6- 18/6, 22/6, 23/6
24-Jun-24	7-Jul-24	10-Jul-24	16.6	17.7	19.7	129896	135972	137184	Boiler offline 24/6, 30/6, 6/7-7/7
8-Jul-24	21-Jul-24	24-Jul-24	15.4	17.3	18.8	74784	125367	137184	Boiler offline 8/7, 9/7 & 21/7
22-Jul-24	4-Aug-24	7-Aug-24	16.1	17.3	18.6	101316	132122	137184	Boiler offline 22/7, 26/7-28/7
5-Aug-24	18-Aug-24	21-Aug-24	17.0	18.1	19.4	136755	137145	137184	Boiler offline 9/8, 17/8-18/8

Sampling Point: Monitoring Point 10 - Stockpile Sediment Pond West
 Licence: Cape Byron Management Pty Ltd
 Location: Broadwater Power Plant Fuel Stockpile
 EPL No: 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameter/s Monitored: See Table
 Frequency & Method: Monthly Grab Sample
 Limit/s: None Prescribed



PARAMETERS MEASURED

Date Sampled	Date Received	Date Published	BOD ₅ (mg/L)	TSS (mg/L)	pH	Nitrogen (mg/L)	Phosphorus (mg/L)	Notes
18-May-22	26-May-22	1-Jun-22	7.7	23	6.1	1.3	0.8	
21-Jun-22	30-Jun-22	27-Jul-22	3.7	15	6.3	0.9	0.9	
22-Jul-22	2-Aug-22	10-Aug-22	4.2	44	6.2	0.9	0.9	
18-Aug-22	26-Aug-22	7-Sep-22	1.9	23	6.6	0.7	1.3	
15-Sep-22	26-Sep-22	5-Oct-22	2.2	10	5.8	1.4	1.3	
18-Oct-22	27-Oct-22	16-Nov-22	3.6	19	6.6	0.6	0.8	
21-Nov-22	1-Dec-22	14-Dec-22	2.3	5	7.0	0.8	0.9	
19-Dec-22	3-Jan-23	11-Jan-23	2.9	10	7.0	1.1	0.6	
18-Jan-23	27-Jan-23	8-Feb-23	1.8	2	6.9	0.6	0.6	
21-Feb-23	3-Mar-23	8-Mar-23	2.7	5	6.8	0.7	0.7	
21-Mar-23	31-Mar-23	5-Apr-23	2.3	23	6.4	0.7	0.9	
18-Apr-23	28-Apr-23	17-May-23	4.7	26	6.6	0.6	0.6	
18-May-23	1-Jun-23	14-Jun-23	8.5	235	6.2	0.7	1.0	
19-Jun-23	29-Jun-23	12-Jul-23	1.4	10	6.5	0.5	0.6	
18-Jul-23	1-Aug-23	9-Aug-23	2.6	10	6.6	0.4	0.4	
17-Aug-23	30-Aug-23	6-Sep-23	1.4	11	6.7	0.6	0.3	
18-Sep-23	17-Oct-23	18-Oct-23	<1	4	7.1	0.5	0.2	
17-Oct-23	23-Oct-23	1-Nov-23	2.1	8	7.1	0.6	0.2	
20-Nov-23	5-Dec-23	13-Dec-23	3.5	15	6.5	0.6	0.8	
19-Dec-23	5-Jan-24	10-Jan-24	0.3	18	6.7	0.5	0.6	
17-Jan-24	30-Jan-24	7-Feb-24	20.5	228	6.4	1.1	1.3	
19-Feb-24	29-Feb-24	6-Mar-24	5.9	46	6.6	0.8	0.9	
19-Mar-24	28-Mar-24	3-Apr-24	7.7	104	6.6	1.2	1.0	
16-Apr-24	30-Apr-24	1-May-24	3.8	91	6.6	1.0	1.1	
20-May-24	28-May-24	29-May-24	7.9	308	6.3	1.4	1.3	
17-Jun-24	27-Jun-24	10-Jul-24	4.6	31	6.5	0.8	0.4	
18-Jul-24	24-Jul-24	7-Aug-24	4.1	103	6.7	0.6	1.6	
20-Aug-24	NR	21-Aug-24	N/A	N/A	N/A	N/A	N/A	

Sampling Point:
 Licencee
 Location
 EPL No
 Parameters Measured
 Frequency & Method
 Licence Limits

Monitoring Point 12 - Reverse Osmosis S
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425
 See Table
 Biannual Grab Sample
 Not Prescribed



Pollutants	Units	Results	Notes
Aluminium	mg/l	0.695	
		0.205	
		0.449	
		0.584	
		0.693	
		0.325	
Ammonia	mg/l	1.320	
		0.680	
		0.292	
		0.998	
		0.116	
		0.751	
Arsenic	mg/l	0.038	
		0.066	
		0.003	
		0.001	
		0.003	
		0.002	
Barium	mg/l	0.003	
		0.002	
		0.003	
		0.002	
		0.002	
		0.002	
Bicarbonate	CaCO ₃ /kg	0.118	
		0.078	
		0.070	
		0.137	
		0.093	
		0.055	
Calcium	mg/l	0.049	
		37	
		120	
		238	
		105	
		105	
Cadmium	mg/l	94	
		30	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
Chloride	mg/l	<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
Chromium	mg/l	26.3	
		33.7	
		70.4	
		35.8	
		36.0	
		43.6	
Chromium	mg/l	6.9	
		2.206	
		1.389	
		108	
		213	
		261	
Chromium	mg/l	232	
		51	
		0.001	
		<0.001	
		0.001	
		0.001	
Conductivity	dS/m	0.001	
		0.002	
		0.001	
		0.001	
		0.001	
		0.001	
Copper	mg/l	1.170	
		0.825	
		0.917	
		1.020	
		1.181	
		1.106	
Copper	mg/l	0.249	
		<0.001	
		<0.001	
		0.001	

Sampling Point:
 Licencee
 Location
 EPL No
 Parameters Measured
 Frequency & Method
 Licence Limits

Monitoring Point 12 - Reverse Osmosis S
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425
 See Table
 Biannual Grab Sample
 Not Prescribed



Pollutants	Units	Results	Notes
		<0.001	
		<0.001	
		<0.001	
		<0.001	
Hardness (as calcium)	CaCO3/kg	142.124	
		33.7	
		241	
		36	
		178	
		189	
		39	
Iron	mg/l	7.673	
		1.35	
		6.77	
		8.06	
		5.97	
		5.42	
		13.90	
Lead	mg/l	<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
Magnesium	mg/l	18.6	
		15.5	
		15.9	
		23.0	
		21.4	
		19.5	
		5.4	
Manganese	mg/l	0.154	
		0.046	
		0.078	
		0.110	
		0.107	
		0.046	
		0.129	
Mercury	mg/l	<0.0005	
		<0.0005	
		<0.0005	
		<0.0005	
		<0.0005	
		<0.0005	
		<0.0005	
Nickel	mg/l	0.002	
		<0.001	
		<0.001	
		<0.01	
		<0.001	
		<0.001	
		<0.001	
Nitrate	mg/l	0.016	
		0.623	
		0.135	
		0.034	
		<0.05	
		<0.005	
		0.020	
Nitrite	mg/l	0.248	
		0.100	
		0.020	
		0.010	
		0.563	
		0.009	
		0.026	
Orthophosphate	mg/l	0.027	
		0.007	
		0.016	
		0.012	
		0.369	
		0.062	

Sampling Point:
 Licence
 Location
 EPL No
 Parameters Measured
 Frequency & Method
 Licence Limits

Monitoring Point 12 - Reverse Osmosis
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425
 See Table
 Biannual Grab Sample
 Not Prescribed



Pollutants	Units	Results	Notes
		0.007	
Potassium	mg/l	8.177	
		11.0	
		14.7	
		12.6	
		21.0	
		14.1	
		3.7	
Selenium	mg/l	<0.002	
		<0.002	
		<0.002	
		<0.002	
		<0.002	
		<0.002	
Silica (total)	mg/l	23.467	
		20.4	
		30.1	
		29.4	
		26.9	
		25.8	
		8.2	
Silver	mg/l	<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
		<0.001	
Sodium	mg/l	175	
		113	
		108	
		157	
		152	
		178	
		35	
Sodium Adsorption Ratio	mg/l	6.394	
		4.0	
		3.0	
		5.0	
		4.9	
		5.6	
		2.4	
Sulfate	mg/l	115	
		87	
		67	
		92	
		109	
		177	
		14	
Total Dissolved Salts	mg/l	796	
		561	
		624	
		692	
		803	
		752	
		169	
Total Organic Carbon	mg/l	21.5	
		20.4	
		23.5	
		24.6	
		31.3	
		25.5	
		8.9	
Total Suspended Solids	mg/l	<1	
		<1	
		<1	
		<1	
		3	
		<1	
		25	
Zinc	mg/l	0.024	
		0.004	
		0.053	

Sampling Point: Monitoring Point 12 - Reverse Osmosis S
 Licencee: Cape Byron Management Pty Ltd
 Location: Broadwater Cogeneration Power Plant
 EPL No: 20425
 Parameters Measured: See Table
 Frequency & Method: Biannual Grab Sample
 Licence Limits: Not Prescribed



Pollutants	Units	Results	Notes
		0.052	
		0.015	
		0.006	
		0.029	
pH		6.78	
		7.60	
		7.84	
		7.35	
		7.23	
		6.94	
		6.97	

Sampling Point: **Monitoring Point 11 - Stockpile Sediment Pond East**
 Licencee Cape Byron Management Pty Ltd
 Location Broadwater Power Plant Fuel Stockpile
 EPL No 20425 <http://www.epa.nsw.gov.au/prpoeoapp/>
 Parameter/s Monitored See Table
 Frequency & Method Monthly Grab Sample
 Limit/s None Prescribed



			PARAMETERS MEASURED					
Date Sampled	Date Received	Date Published	BOD ₅ (mg/L)	TSS (mg/L)	pH	Nitrogen (mg/L)	Phosphorus (mg/L)	Notes
31-Jan-22	NA	NA	NR	NR	NR	NR	NR	Flood affected operations
25-Feb-22	NA	NA	NR	NR	NR	NR	NR	Pond sample unable to be taken due to flooding in Feb
20-Mar-22	NA	NA	NR	NR	NR	NR	NR	Pond sample unable to be taken due to flooding in Feb
29-Apr-22	10-May-22	18-May-22	4.2	4	7.2	0.9	0.2	
18-May-22	26-May-22	1-Jun-22	5.4	9	7.1	1.4	0.4	
21-Jun-22	30-Jun-22	27-Jul-22	3.2	8	7.2	1.1	0.3	
22-Jul-22	2-Aug-22	10-Aug-22	2.4	30	7.0	1.4	0.3	
18-Aug-22	26-Aug-22	7-Sep-22	5.2	23	7.2	1.8	0.6	
15-Sep-22	26-Sep-22	5-Oct-22	3.3	13	7.0	1.2	0.4	
18-Oct-22	27-Oct-22	16-Nov-22	4.3	12	6.9	1.0	0.4	
21-Nov-22	1-Dec-22	14-Dec-22	12.8	14	8.1	4.0	0.9	
19-Dec-22	3-Jan-23	11-Jan-23	11.5	105	8.0	4.2	0.9	
18-Jan-23	27-Jan-23	8-Feb-23	16.7	29	9.3	3.4	0.8	
21-Feb-23	3-Mar-23	8-Mar-23	5.1	17	7.6	2.3	0.6	
21-Mar-23	31-Mar-23	5-Apr-23	5.9	19	7.6	2.8	0.6	
18-Apr-23	28-Apr-23	17-May-23	7.1	12	7.4	1.8	0.3	
18-May-23	1-Jun-23	14-Jun-23	2.9	28	7.3	1.5	0.3	
19-Jun-23	29-Jun-23	12-Jul-23	3.7	27	7.3	1.9	0.3	
18-Jul-23	1-Aug-23	9-Aug-23	7.0	21	7.5	1.7	0.3	
17-Aug-23	30-Aug-23	6-Sep-23	21.4	34	6.9	2.2	0.5	
18-Sep-23	17-Oct-23	18-Oct-23	7.2	25	8.7	2.3	0.5	
17-Oct-23	23-Oct-23	1-Nov-23	27.7	52	9.9	6.0	1.0	
20-Nov-23	5-Dec-23	13-Dec-23	4.2	13	7.3	1.4	0.5	
19-Dec-23	5-Jan-24	10-Jan-24	4.7	16	7.8	1.5	0.6	
17-Jan-24	30-Jan-24	7-Feb-24	8.5	45	9.8	3.3	0.5	
19-Feb-24	29-Feb-24	6-Mar-24	4.9	14	8.1	1.8	0.4	
19-Mar-24	28-Mar-24	3-Apr-24	6.2	16	7.8	1.8	0.4	
16-Apr-24	30-Apr-24	1-May-24	4.4	8	7.5	1.3	0.4	
20-May-24	28-May-24	29-May-24	4.2	9	7.2	1.1	0.3	
17-Jun-24	27-Jun-24	10-Jul-24	<1	4	7.2	1.6	0.4	
18-Jul-24	24-Jul-24	7-Aug-24	3.0	14	7.4	1.6	0.4	
20-Aug-24	NR	21-Aug-24	N/A	N/A	N/A	N/A	N/A	

Sampling Point:
 Licencee
 Location
 EPL No
 Parameter/s Monitored
 Frequency & Method

Rain gauge
 Cape Byron Management Pty Ltd
 Broadwater Cogeneration Power Plant
 20425
 Rainfall
 Continuous Auto Sampler



TIPPING GAUGE CONTINUOUS RAINFALL MONITORING					
Period From		Period To		Daily Rain	
Date	Time	Date	Time	Total (mm)	Max Intensity (mm/min)
Sunday, 16 June 2024	9:01am	Monday, 17 June 2024	9:00am	0.4	0.2
Monday, 17 June 2024	9:01am	Tuesday, 18 June 2024	9:00am	0	0
Tuesday, 18 June 2024	9:01am	Wednesday, 19 June 2024	9:00am	0	0
Wednesday, 19 June 2024	9:01am	Thursday, 20 June 2024	9:00am	0	0
Thursday, 20 June 2024	9:01am	Friday, 21 June 2024	9:00am	0	0
Friday, 21 June 2024	9:01am	Saturday, 22 June 2024	9:00am	0	0
Saturday, 22 June 2024	9:01am	Sunday, 23 June 2024	9:00am	0	0
Sunday, 23 June 2024	9:01am	Monday, 24 June 2024	9:00am	0.2	0.2
Monday, 24 June 2024	9:01am	Tuesday, 25 June 2024	9:00am	0.2	0.2
Tuesday, 25 June 2024	9:01am	Wednesday, 26 June 2024	9:00am	2.2	0.2
Wednesday, 26 June 2024	9:01am	Thursday, 27 June 2024	9:00am	0.2	0.2
Thursday, 27 June 2024	9:01am	Friday, 28 June 2024	9:00am	0	0
Friday, 28 June 2024	9:01am	Saturday, 29 June 2024	9:00am	0.2	0.2
Saturday, 29 June 2024	9:01am	Sunday, 30 June 2024	9:00am	0	0
Sunday, 30 June 2024	9:01am	Monday, 1 July 2024	9:00am	3.6	0.2
Monday, 1 July 2024	9:01am	Tuesday, 2 July 2024	9:00am	25.4	0.8
Tuesday, 2 July 2024	9:01am	Wednesday, 3 July 2024	9:00am	41.2	1.8
Wednesday, 3 July 2024	9:01am	Thursday, 4 July 2024	9:00am	21	0.8
Thursday, 4 July 2024	9:01am	Friday, 5 July 2024	9:00am	18.2	1
Friday, 5 July 2024	9:01am	Saturday, 6 July 2024	9:00am	21.2	1.2
Saturday, 6 July 2024	9:01am	Sunday, 7 July 2024	9:00am	7.2	0.6
Sunday, 7 July 2024	9:01am	Monday, 8 July 2024	9:00am	16.4	1.8
Monday, 8 July 2024	9:01am	Tuesday, 9 July 2024	9:00am	1.8	0.2
Tuesday, 9 July 2024	9:01am	Wednesday, 10 July 2024	9:00am	0.6	0.2
Wednesday, 10 July 2024	9:01am	Thursday, 11 July 2024	9:00am	0.2	0.2
Thursday, 11 July 2024	9:01am	Friday, 12 July 2024	9:00am	0.2	0.2
Friday, 12 July 2024	9:01am	Saturday, 13 July 2024	9:00am	0	0
Saturday, 13 July 2024	9:01am	Sunday, 14 July 2024	9:00am	0	0
Sunday, 14 July 2024	9:01am	Monday, 15 July 2024	9:00am	0	0
Monday, 15 July 2024	9:01am	Tuesday, 16 July 2024	9:00am	0	0
Tuesday, 16 July 2024	9:01am	Wednesday, 17 July 2024	9:00am	0	0
Wednesday, 17 July 2024	9:01am	Thursday, 18 July 2024	9:00am	0	0
Thursday, 18 July 2024	9:01am	Friday, 19 July 2024	9:00am	0	0
Friday, 19 July 2024	9:01am	Saturday, 20 July 2024	9:00am	0	0
Saturday, 20 July 2024	9:01am	Sunday, 21 July 2024	9:00am	0	0
Sunday, 21 July 2024	9:01am	Monday, 22 July 2024	9:00am	0	0
Monday, 22 July 2024	9:01am	Tuesday, 23 July 2024	9:00am	0	0
Tuesday, 23 July 2024	9:01am	Wednesday, 24 July 2024	9:00am	0.2	0.2
Wednesday, 24 July 2024	9:01am	Thursday, 25 July 2024	9:00am	0.2	0.2
Thursday, 25 July 2024	9:01am	Friday, 26 July 2024	9:00am	0	0
Friday, 26 July 2024	9:01am	Saturday, 27 July 2024	9:00am	0.2	0.2
Saturday, 27 July 2024	9:01am	Sunday, 28 July 2024	9:00am	4.8	0.4
Sunday, 28 July 2024	9:01am	Monday, 29 July 2024	9:00am	0	0
Monday, 29 July 2024	9:01am	Tuesday, 30 July 2024	9:00am	0	0
Tuesday, 30 July 2024	9:01am	Wednesday, 31 July 2024	9:00am	0	0
Wednesday, 31 July 2024	9:01am	Thursday, 1 August 2024	9:00am	0	0
Thursday, 1 August 2024	9:01am	Friday, 2 August 2024	9:00am	0	0
Friday, 2 August 2024	9:01am	Saturday, 3 August 2024	9:00am	0	0
Saturday, 3 August 2024	9:01am	Sunday, 4 August 2024	9:00am	0.2	0.2
Sunday, 4 August 2024	9:01am	Monday, 5 August 2024	9:00am	0	0
Monday, 5 August 2024	9:01am	Tuesday, 6 August 2024	9:00am	0.2	0.2
Tuesday, 6 August 2024	9:01am	Wednesday, 7 August 2024	9:00am	0	0
Wednesday, 7 August 2024	9:01am	Thursday, 8 August 2024	9:00am	0.2	0.2
Thursday, 8 August 2024	9:01am	Friday, 9 August 2024	9:00am	0.4	0.2
Friday, 9 August 2024	9:01am	Saturday, 10 August 2024	9:00am	0.4	0.2
Saturday, 10 August 2024	9:01am	Sunday, 11 August 2024	9:00am	11.8	0.8
Sunday, 11 August 2024	9:01am	Monday, 12 August 2024	9:00am	137.2	1.8
Monday, 12 August 2024	9:01am	Tuesday, 13 August 2024	9:00am	86.4	1.4
Tuesday, 13 August 2024	9:01am	Wednesday, 14 August 2024	9:00am	15.4	1
Wednesday, 14 August 2024	9:01am	Thursday, 15 August 2024	9:00am	11.8	0.2
Thursday, 15 August 2024	9:01am	Friday, 16 August 2024	9:00am	4.6	0.2
Friday, 16 August 2024	9:01am	Saturday, 17 August 2024	9:00am	0.2	0.2
Saturday, 17 August 2024	9:01am	Sunday, 18 August 2024	9:00am	0	0
Sunday, 18 August 2024	9:01am	Monday, 19 August 2024	9:00am	0	0
Monday, 19 August 2024	9:01am	Tuesday, 20 August 2024	9:00am	5.8	0.2
Tuesday, 20 August 2024	9:01am	Wednesday, 21 August 2024	9:00am	0.2	0.2

Licencee Cape Byron Management Pty Ltd
 Location Broadwater Cogeneration Power Plant
 EPL No 20425



CORRECTIONS LOG

Date Sampled	Monitoring Point	Pollutant/Parameter	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
01-Jul-21	3	PM10	<0.1	5.0	23-Sep-21	13-Aug-21	Sample and bag mixed up
31-Jul-21	3	PM10	5.0	11.9	23-Sep-21	13-Aug-21	Sample and bag mixed up
20/3/23	9	Cogen CW in	0.2	21.5	04-Jul-23	20/3/23	Analyser offline
3-Apr-23	9	Mean daily intake	1196474.0	119647	04-Jul-23	3-Apr-23	V2
4-Dec-24	9	Inlet Temperature	83.0	36.3	23-Jul-24	13-Dec-23	Data not correct due to testing on instrumentation

117 Baraang Drive Broadwater NSW