



Environmental Monitoring Report V2

Condong Biomass Power Plant 153 McLeod Street Condong NSW

Licencee Cape Byron Management Pty Ltd
Address 153 McLeod Street Condong NSW
EPL No 20424 <http://www.epa.nsw.gov.au/prpoeoapp/>

This data is published under section 66(6) of the *Protection of the Environment Operations Act 1997*

Sampling Point:
 Licencee
 Location
 EPL No
 Parameters Monitored
 Frequency & Method

Monitoring Point 1 - No 1 Boiler Stack Emissions
 Cape Byron Management Pty Ltd
 Condong Cogeneration Power Plant
 20424 www.environment.nsw.gov.au
 see individual parameters in table
 Annually in accordance with EPA protocols



Limits see individual parameters in table

Test Number	AE14761	AE14992	AE15185	AE15315	AE15396	AE15579	AE15683
Sampling Date	7/02/2023	18/05/2023	14/09/2023	11/12/2023	17/01/2024	17/04/2024	6/06/2024
Date Received	21/03/2023	2/06/2023	4/10/2023	31/01/2024	12/02/2024	1/05/2024	1/08/2024
Date Published	22/03/2023	14/06/2023	1/11/2023	7/02/2024	21/02/2024	15/05/2024	7/08/2024

Measured Parameters dry @ STP and corrected to 7% O ₂	Units	Concentration Limit							
Average stack gas temperature	°C	Not Applicable	59.80	59.60	59.80	58.30	63.30	59.30	60.00
Average velocity at sampling plane	m/s	Not Applicable	15.40	15.40	24.00	20.40	18.90	18.50	13.80
Dry Gas Volumetric Flowrate	m ³ /sec	Not Applicable	67.33	61.11	106.60	94.30	82.83	84.70	65.86
Dry Gas Density	kg/m ³	Not Applicable	1.33	1.31	1.34	1.34	1.33	1.33	1.33
Molecular Weight of Stack Gases	g/g mole	Not Applicable	29.60	29.30	30.00	30.00	29.90	29.80	29.70
Moisture content	%	Not Applicable	17.1	11.5	15.4	11.4	14.2	12.1	8.3
Concentration of carbon dioxide	%	Not Applicable	5.88	4.27	9.88	9.53	8.66	8.4	8.43
Total Solid Particles	mg/m ³	100.00	29.40	90.00	58.90	70.90	38.20	7.55	9.94
Sulphuric Acid Mist & Sulphur Trioxide as SO ₃	mg/m ³	30.00	2.29	2.60	16.30	5.56	7.50	0.03	0.03
Nitrogen Oxides (NO _x)	mg/m ³	500.00	156.00	261.00	373.00	271.00	174.00	174.00	276.00

Sampling Point: Monitoring Point 2 - Ambient Air Monitoring Fuel Stockpile
 Licence: Cape Byron Management Pty Ltd
 Location: Condong Cogeneration Power Plant
 EPL No: 20424
 Parameters Monitored: Particulates - Deposited Matter
 Monitoring Frequency: Continuous with sample results extrapolated from sample period of 30 ± 2 days
 Limits: Not Applicable
 Comments: Laboratory Analysis



Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
04-Jan-22	21-Jan-22	28-Jan-22	7.79	
01-Feb-22	NA	22-Apr-22	NA	Flood damage to plant operations
01-Mar-22	NA	22-Apr-22	NA	Bottles flood damaged and not serviceable, new bottles set 08/04/2022, plant not operational
05-May-22	09-May-22	18-May-22	4.52	Fine org. matter
06-Jun-22	17-Jun-22	29-Jun-22	0.56	Organic matter
04-Jul-22	08-Aug-22	10-Aug-22	3.03	Cloudy
08-Aug-22	NA	NA	NA	Bottle smashed at EAL
06-Sep-22	12-Sep-22	21-Sep-22	2.16	Organic matter
06-Oct-22	13-Oct-22	19-Oct-22	1.93	
02-Nov-22	04-Nov-22	16-Nov-22	0.90	
07-Dec-22	20-Dec-22	25-Jan-23	2.03	Fine org. matter
11-Jan-23	12-Jan-23	25-Jan-23	2.64	dead beetle
03-Feb-23	10-Feb-23	22-Feb-23	0.73	
08-Mar-23	15-Mar-23	22-Mar-23	4.91	bugs, fine org. matter
03-Apr-23	14-Apr-23	19-Apr-23	3.40	fine org. matter
04-May-23	11-May-23	17-May-23	3.88	small spider, fine org. matter
02-Jun-23	07-Jun-23	28-Jun-23	2.75	Fine Organic Matter
03-Jul-23	10-Jul-23	12-Jul-23	6.36	Fine org. matter, cloudy
07-Aug-23	10-Aug-23	23-Aug-23	4.62	Fine org. matter, cloudy
04-Sep-23	19-Sep-23	20-Sep-23	5.08	Ash, fine org. matter, cloudy, brown
03-Oct-23	11-Oct-23	19-Oct-23	4.87	Fine org. matter
02-Nov-23	08-Nov-23	16-Nov-23	2.87	Org. matter, cloudy, brown
04-Dec-23	13-Dec-23	13-Dec-23	6.93	Bugs, algae, fine org. matter
04-Jan-24	12-Jan-24	24-Jan-24	3.52	Mosquitos, fine org. matter
05-Feb-24	09-Feb-24	21-Feb-24	9.32	Bugs, fine org. matter
04-Mar-24	08-Mar-24	20-Mar-24	1.48	
04-Apr-24	05-Apr-24	26-Jun-24	3.11	seeds, moth, insects, fine org. matter, cloudy
04-May-24	07-May-24	26-Jun-24	1.94	dead bugs, fine org. matter, cloudy, brown
04-Jun-24	17-Jun-24	26-Jun-24	3.58	Spider web, bugs, leaves, fine org. matter
03-Jul-24	12-Jul-05	24-Jul-24	5.52	Small insects, fine org. matter, cloudy
02-Aug-24	08-Aug-24	21-Aug-24	0.91	sediment, fine org. matter, cloudy

Sampling Point: Monitoring Point 2 - Ambient Air Monitoring Fuel Stockpile
 Licencee Cape Byron Management Pty Ltd
 Location Condong Cogeneration Power Plant
 EPL No 20424
 Parameters Monitored PM10
 Monitoring Frequency Once every 6 days when operating at stockpile
 Limits Not Applicable
 Comments



Date Sample Collected	Date Received	Date Published	Results (ug/m ³)	Notes
03-Jan-23	19-Jan-23	25-Jan-23	12.2	
09-Jan-23	01-Mar-23	08-Mar-23	9.3	
15-Jan-23	01-Mar-23	08-Mar-23	6.2	
21-Jan-23	01-Mar-23	08-Mar-23	11.4	
27-Jan-23	01-Mar-23	08-Mar-23	15.4	
02-Feb-23	01-Mar-23	08-Mar-23	12.4	
08-Feb-23	20-Mar-23	22-Mar-23	48.4	
14-Feb-23	20-Mar-23	22-Mar-23	25.2	
20-Feb-23	20-Mar-23	22-Mar-23	9.0	
26-Feb-23	20-Mar-23	22-Mar-23	11.0	
04-Mar-23	20-Mar-23	22-Mar-23	26.2	
10-Mar-23	14-Apr-23	19-Apr-23	41.1	
16-Mar-23	14-Apr-23	19-Apr-23	28.6	
22-Mar-23	14-Apr-23	19-Apr-23	14.0	
28-Mar-23	14-Apr-23	19-Apr-23	16.3	
03-Apr-23	14-Apr-23	19-Apr-23	9.2	
09-Apr-23	20-Jun-23	28-Jun-23	11.1	
15-Apr-23	20-Jun-23	28-Jun-23	40.6	
21-Apr-23	20-Jun-23	28-Jun-23	47.4	
27-Apr-23	20-Jun-23	28-Jun-23	9.1	
03-May-23	20-Jun-23	28-Jun-23	50.4	
09-May-23	20-Jun-23	28-Jun-23	59.4	
15-May-23	20-Jun-23	28-Jun-23	7.3	
21-May-23	20-Jun-23	28-Jun-23	14.3	
27-May-23	20-Jun-23	28-Jun-23	23.7	
02-Jun-23	20-Jun-23	28-Jun-23	44.9	
08-Jun-23	14-Jul-23	26-Jul-23	18.4	
14-Jun-23	14-Jul-23	26-Jul-23	21.9	
20-Jun-23	14-Jul-23	26-Jul-23	40.8	
26-Jun-23	14-Jul-23	26-Jul-23	12.4	
02-Jul-23	14-Jul-23	26-Jul-23	30.3	
08-Jul-23	21-Aug-23	23-Aug-23	16.3	
14-Jul-23	21-Aug-23	23-Aug-23	31.2	
20-Jul-23	21-Aug-23	23-Aug-23	14.6	
26-Jul-23	21-Aug-23	23-Aug-23	26.7	
01-Aug-23	21-Aug-23	23-Aug-23	37.1	
07-Aug-23	21-Aug-23	23-Aug-23	8.1	
13-Aug-23	18-Sep-23	20-Sep-23	29.2	
19-Aug-23	18-Sep-23	20-Sep-23	25.0	
25-Aug-23	18-Sep-23	20-Sep-23	36.0	
31-Aug-23	18-Sep-23	20-Sep-23	15.3	
06-Sep-23	11-Oct-23	19-Oct-23	15.8	
12-Sep-23	11-Oct-23	19-Oct-23	39.3	
18-Sep-23	11-Oct-23	19-Oct-23	11.5	
24-Sep-23	11-Oct-23	19-Oct-23	24.6	
30-Sep-23	11-Oct-23	19-Oct-23	13.6	
06-Oct-23	16-Nov-23	29-Nov-23	15.9	
12-Oct-23	16-Nov-23	29-Nov-23	31.4	
18-Oct-23	16-Nov-23	29-Nov-23	65.1	
24-Oct-23	16-Nov-23	29-Nov-23	35.7	
30-Oct-23	16-Nov-23	29-Nov-23	NA	Paper damaged on retrieval due to wind gust
05-Nov-23	21-Dec-23	27-Dec-23	10.6	
11-Nov-23	21-Dec-23	27-Dec-23	13.9	
17-Nov-23	21-Dec-23	27-Dec-23	50.5	
23-Nov-23	21-Dec-23	27-Dec-23	17.6	
29-Nov-23	21-Dec-23	27-Dec-23	13.6	
05-Dec-23	21-Dec-23	27-Dec-23	35.7	
11-Dec-23	05-Feb-24	07-Feb-24	17.8	
17-Dec-23	05-Feb-24	07-Feb-24	17.9	
23-Dec-23	05-Feb-24	07-Feb-24	10.7	
29-Dec-23	05-Feb-24	07-Feb-24	14.6	
03-Jan-24	05-Feb-24	07-Feb-24	17.2	
09-Jan-24	05-Feb-24	07-Feb-24	11.0	
15-Jan-24	04-Mar-24	06-Mar-24	11.5	
21-Jan-24	04-Mar-24	06-Mar-24	14.4	
27-Jan-24	04-Mar-24	06-Mar-24	24.4	
02-Feb-24	15-Mar-24	20-Mar-24	22.3	
08-Feb-24	15-Mar-24	20-Mar-24	8.8	
14-Feb-24	15-Mar-24	20-Mar-24	51.7	
20-Feb-24	15-Mar-24	20-Mar-24	22.0	
26-Feb-24	15-Mar-24	20-Mar-24	17.7	
03-Mar-24	18-Apr-24	01-May-24	10.1	
09-Mar-24	18-Apr-24	01-May-24	14.2	
15-Mar-24	18-Apr-24	01-May-24	19.4	
21-Mar-24	18-Apr-24	01-May-24	14.6	
27-Mar-24	18-Apr-24	01-May-24	4.5	
02-Apr-24	18-Apr-24	01-May-24	NA	Paper damaged on retrieval due to wind gust
08-Apr-24	13-May-24	29-May-24	19.8	
14-Apr-24	13-May-24	29-May-24	10.9	
20-Apr-24	13-May-24	29-May-24	9.0	
26-Apr-24	13-May-24	29-May-24	14.7	
02-May-24	13-May-24	29-May-24	7.4	
08-May-24	13-May-24	29-May-24	9.3	
14-May-24	13-May-24	29-May-24	33.9	
20-May-24	13-May-24	29-May-24	67.9	
26-May-24	13-May-24	29-May-24	8.9	
01-Jun-24	13-May-24	29-May-24	7.5	
07-Jun-24	12-Jul-24	24-Jul-24	55.3	
13-Jun-24	12-Jul-24	24-Jul-24	67.8	
19-Jun-24	12-Jul-24	24-Jul-24	40.0	
25-Jun-24	12-Jul-24	24-Jul-24	11.4	
01-Jul-24	12-Jul-24	24-Jul-24	8.2	
07-Jul-24	19-Aug-24	21-Aug-24	4.8	
13-Jul-24	19-Aug-24	21-Aug-24	27.6	
19-Jul-24	19-Aug-24	21-Aug-24	38.1	
25-Jul-24	19-Aug-24	21-Aug-24	17.3	

Sampling Point: **Monitoring Point 2 - Ambient Air Monitoring Fuel Stockpile**
Licencee Cape Byron Management Pty Ltd
Location Condong Cogeneration Power Plant
EPL No 20424
Parameters Monitored [PM10](#)
Monitoring Frequency Once every 6 days when operating at stockpile
Limits Not Applicable
Comments



Date Sample Collected	Date Received	Date Published	Results (ug/m ³)	Notes
31-Jul-24	19-Aug-24	21-Aug-24	56.9	

Sampling Point: Monitoring Point 4 - Ambient Air Monitoring North of Bowling Club
 Licence: Cape Byron Management Pty Ltd
 Location: Condong Cogeneration Power Plant
 EPL No: 20424
 Parameters Monitored: [Particulates - Deposited Matter](#)
 Monitoring Frequency: Continuous with sample results extrapolated from sample period of 30 ± 2 days



Limits: Not Applicable

Comments: Laboratory Analysis

Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
04-Jan-22	21-Jan-22	28-Jan-22	3.42	Fine org. matter
01-Feb-22	NA	22-Apr-22	NA	Flood damage to plant operations
01-Mar-22	NA	22-Apr-22	NA	Bottles flood damaged and not serviceable, new bottles set 08/04/2022
05-May-22	09-May-22	18-May-22	1.06	Fine org. matter
06-Jun-22	17-Jun-22	29-Jun-22	0.88	Organic matter
04-Jul-22	08-Aug-22	10-Aug-22	2.86	Bugs, grass Fine Org.Matter
08-Aug-22	12-Aug-22	24-Aug-22	1.22	Dead worm. Fine Org.Matter, Large Org. Matter
06-Sep-22	12-Sep-22	21-Sep-22	2.27	Org. Matter
06-Oct-22	13-Oct-22	19-Oct-22	3.92	Fine Org. Matter
02-Nov-22	04-Nov-22	16-Nov-22	1.43	
07-Dec-22	20-Dec-02	25-Jan-23	3.70	Dead bugs, fine Org. matter
11-Jan-23	12-Jan-23	25-Jan-23	4.55	Fine org. matter
03-Feb-23	10-Feb-23	22-Feb-23	0.18	Org. Matter
08-Mar-23	15-Mar-23	22-Mar-23	0.58	Org. Matter
03-Apr-23	04-Apr-23	19-Apr-23	0.26	Org. Matter
04-May-23	11-May-23	17-May-23	5.40	fine org. matter, cloudy
02-Jun-23	07-Jun-23	28-Jun-23	0.91	dead wasp, fine organic matter
03-Jul-23	10-Jul-23	12-Jul-23	1.80	Bugs, org. matter
07-Aug-23	10-Aug-23	23-Aug-23	0.60	Fine org. matter, cloudy
04-Sep-23	19-Sep-23	20-Sep-23	1.70	Spider, algae, fine org. matter
03-Oct-23	11-Oct-23	19-Oct-23	4.09	Spider, algae, fine org. matter
02-Nov-23	08-Nov-23	16-Nov-23	10.89	Fine org. matter, algae, seeds, ants, cloudy, yellow
04-Dec-23	13-Dec-23	13-Dec-23	28.01	Ants, bugs, algae, fine org. matter, cloudy
04-Jan-24	12-Jan-24	24-Jan-24	0.35	Ants, fine org. matter
05-Feb-24	09-Feb-24	21-Feb-24	5.86	Algae, twig fine org. matter
04-Mar-24	08-Mar-24	20-Mar-24	1.43	Algae, fine org. matter, cloudy, brown
04-Apr-24	05-Apr-24	26-Jun-24	1.35	seeds, leaves, fine org. matter, brown
04-May-24	07-May-24	15-May-24	0.52	fine org. matter
04-Jun-24	17-Jun-24	26-Jun-24	3.09	algae, bugs, fine org. matter, cloudy, yellow
03-Jul-24	12-Jul-24	24-Jul-24	0.70	Ants, insect, algae, fine org. matter
02-Aug-24	08-Aug-24	21-Aug-24	0.97	sediment, fine org. matter

Sampling Point: Monitoring Point 5 - Ambient Air Monitoring South of Mill

Licence Cape Byron Management Pty Ltd
 Location Condong Cogeneration Power Plant
 EPL No 20424



Parameters Monitored **Particulates - Deposited Matter**

Monitoring Frequency Continuous with sample results extrapolated from sample period of 30 ± 2 days

Limits Not Applicable

Comments Laboratory Analysis

Date Sample Collected	Date Received	Date Published	Results (g/m ² /month)	Notes
04-Jan-22	21-Jan-22	28-Jan-22	5.07	Fine org. matter
NA	01-Feb-22	22-Apr-22	NA	Flood damage to plant operations
NA	01-Mar-22	22-Apr-22	NA	Bottles flood damaged and not serviceable, new bottles set 08/04/2021
05-May-22	09-May-22	18-May-22	0.92	Fine org. matter
06-Jun-22	17-Jun-22	29-Jun-22	1.61	Organic matter & algae
04-Jul-22	08-Aug-22	10-Aug-22	2.52	Grasshopper, spider, Org.Matter, Cloudy
08-Aug-22	12-Aug-22	24-Aug-22	1.46	Fine Org. Matter
06-Sep-22	12-Aug-22	21-Sep-22	5.06	Yellow, Cloudy
06-Oct-22	13-Oct-22	19-Oct-22	5.45	Fine Org. Matter
02-Nov-22	04-Nov-22	16-Nov-22	4.02	bugs Org. Matter
07-Dec-02	20-Dec-02	25-Jan-23	1.51	Org. Matter
11-Jan-23	12-Jan-23	25-Jan-23	4.85	Fine org. matter
03-Feb-23	10-Feb-23	22-Feb-23	0.96	small seeds, org. matter
08-Mar-23	15-Mar-23	22-Mar-23	0.73	dead bugs, seeds , fine org. matter, yellow
03-Apr-23	04-Apr-23	22-Mar-23	2.43	Fine Org. Matter
04-May-23	11-May-23	17-May-23	1.23	fine org. matter
02-Jun-23	07-Jun-23	28-Jun-23	6.31	Fine org. matter, large org. matter
03-Jul-23	10-Jul-23	12-Jul-23	2.24	Seeds, fine org. matter
07-Aug-23	10-Aug-23	23-Aug-23	2.79	Bark/ spider, fine org. matter, cloudy
04-Sep-23	19-Sep-23	20-Sep-23	3.26	Ash, bugs, fine org. matter, cloudy, brown
03-Oct-23	11-Oct-23	19-Oct-23	4.61	Org. matter, cloudy
02-Nov-23	08-Nov-23	16-Nov-23	5.00	Fine org. matter, grass
04-Dec-23	13-Dec-23	13-Dec-23	10.33	Algae, bugs, org. matter, cloudy, yellow
04-Jan-24	12-Jan-24	24-Jan-24	0.91	Bugs, fine org. matter
05-Feb-24	09-Feb-24	21-Feb-24	3.51	Ants, twig, fine org. matter
04-Mar-24	08-Mar-24	20-Mar-24	0.71	
04-Apr-24	05-Apr-24	26-Jun-24	0.87	insects, fine org. matter
04-May-24	07-May-24	26-Jun-24	0.58	
04-Jun-24	17-Jun-24	26-Jun-24	1.31	fine org. matter
03-Jul-24	12-Jul-24	24-Jul-24	2.78	fine org. matter, cloudy
02-Aug-24	08-Aug-24	21-Aug-24	1.22	bugs, twigs, fine org. matter

Monitoring Point 6 - O₂ Boiler Prior to Primary Air Heater

Licensee: Cape Byron Management Pty Ltd
 Location: Condong Cogeneration Power Plant
 EPL No: 20424
 Parameter(s) Monitored: Oxygen
 Frequency & Method: Continuous Online Sampling
 Limit: No Limits Prescribed
 Comments: The results in the table provide a summary of the minimum, maximum and mean daily values for the period indicated



MONITORING PERIOD		Oxygen (%)			Notes	
Date Start	Date Finish	Date Published	Minimum Value	Maximum Value		Mean Value
2-Jan-23	8-Jan-23	25-Jan-23	2.03	20.36	12.41	Boiler offline 03/01/2023, 03/01/2023, 06/01/2023, 07/01/2023, 08/01/2023
9-Jan-23	15-Jan-23	25-Jan-23	1.43	20.28	14.48	Boiler offline 08/01/2023, 10/01/2023, 11/01/2023, 13/01/2023, 14/01/2023, 15/01/2023
16-Jan-23	22-Jan-23	25-Jan-23	0.59	20.18	15.18	Boiler offline 16/01/2023, 17/01/2023, 18/01/2023, 19/01/2023, 20/01/2023, 21/01/2023
23-Jan-23	29-Jan-23	8-Feb-23	1.93	20.00	16.90	Boiler offline 23/01/2023, 24/01/2023, 24/01/2023, 24/01/2023, 25/01/2023, 26/01/2023, 27/01/2023, 28/01/2023, 29/01/2023
30-Jan-23	5-Feb-23	8-Feb-23	2.46	19.99	14.02	Boiler offline 30/01/2023, 01/02/2023, 02/02/2023, 03/02/2023, 04/02/2023, 05/02/2023
6-Feb-23	12-Feb-23	22-Feb-23	2.48	20.03	11.00	Boiler offline 06/02/2023, 10/02/2023, 11/02/2023, 12/02/2023
13-Feb-23	19-Feb-23	22-Feb-23	-0.77	20.33	14.88	Boiler offline 13/02/2023, 14/02/2023, 15/02/2023, 16/02/2023, 17/02/2023, 18/02/2023, 19/02/2023
20-Feb-23	26-Feb-23	8-Mar-23	1.73	20.12	11.05	Boiler offline 20/02/2023, 23/02/2023, 24/02/2023, 25/02/2023, 26/02/2023
27-Feb-23	5-Mar-23	8-Mar-23	0.33	20.14	9.52	Boiler offline 27/02/2023, 03/03/2023, 04/03/2023, 05/03/2023
6-Mar-23	12-Mar-23	22-Mar-23	NA	NA	NA	Factory shut down 06/03/2023-19/03/2023 for annual shut down
13-Mar-23	19-Mar-23	22-Mar-23	NA	NA	NA	Factory shut down 06/03/2023-19/03/2023 for annual shut down
20-Mar-23	26-Mar-23	5-Apr-23	0.86	20.00	8.44	Boiler offline 20/03/2023, 26/03/2023
27-Mar-23	2-Apr-23	5-Apr-23	0.86	20.22	8.01	Boiler offline 27/03/2023, 01/04/2023, 02/04/2023
3-Apr-23	9-Apr-23	19-Apr-23	1.60	19.89	10.74	Boiler offline 07/04/2023, 08/04/2023, 09/04/2023
10-Apr-23	16-Apr-23	19-Apr-23	2.38	20.54	11.73	Boiler offline 10/04/2023, 10/04/2023, 10/04/2023, 10/04/2023
17-Apr-23	23-Apr-23	3-May-23	1.49	19.92	10.06	Boiler offline 21/04/2023, 22/04/2023, 24/04/2023
24-Apr-23	30-Apr-23	3-May-23	1.00	20.21	12.48	Boiler offline 24/04/2023, 25/05/2023, 29/05/2023, 30/05/2023
1-May-23	7-May-23	17-May-23	1.61	20.48	11.11	Boiler offline 01/05/2023, 03/05/2023, 06/05/2023, 07/05/2023
8-May-23	14-May-23	17-May-23	1.92	20.51	11.13	Boiler offline 08/05/2023, 12/05/2023, 13/05/2023
15-May-23	21-May-23	31-May-23	2.92	20.37	17.92	Boiler offline 15/05/2023, 16/05/2023, 17/05/2023, 18/05/2023, 19/05/2023, 20/05/2023, 21/05/2023
22-May-23	28-May-23	31-May-23	1.83	20.41	12.48	Boiler offline 22/05/2023, 23/05/2023, 27/05/2023, 28/05/2023
29-May-23	4-Jun-23	14-Jun-23	2.60	20.42	11.02	Boiler offline 29/05/2023, 30/05/2023, 02/06/2023, 03/06/2023, 04/06/2023
5-Jun-23	11-Jun-23	14-Jun-23	2.32	19.96	10.81	Boiler offline 05/06/2023, 06/06/2023, 10/06/2023, 11/06/2023
12-Jun-23	18-Jun-23	28-Jun-23	-0.77	21.07	15.00	Boiler offline 12/06/2023, 15/06/2023, 16/06/2023, 17/06/2023
19-Jun-23	25-Jun-23	28-Jun-23	1.57	20.62	10.66	Boiler offline 19/06/2023, 23/06/2023, 24/06/2023, 25/06/2023
26-Jun-23	2-Jul-23	12-Jul-23	-0.02	20.35	11.39	Boiler offline 26/06/2023, 30/06/2023, 01/07/2023, 02/07/2024
3-Jul-23	9-Jul-23	12-Jul-23	0.00	20.27	6.61	Boiler offline 03/07/2023, 05/07/2023, 06/07/2023
10-Jul-23	16-Jul-23	26-Jul-23	0.00	6.86	1.94	
17-Jul-23	23-Jul-23	26-Jul-23	0.00	6.66	2.28	
24-Jul-23	30-Jul-23	9-Aug-23	0.00	5.20	1.68	
31-Jul-23	6-Aug-23	9-Aug-23	-0.77	20.38	3.90	Boiler offline 01/08/2023
7-Aug-23	13-Aug-23	23-Aug-23	0.00	13.89	2.04	
14-Aug-23	20-Aug-23	23-Aug-23	0.00	19.85	2.14	Boiler shutdown 17/08/2023 - 12:45-14:15
21-Aug-23	27-Aug-23	6-Sep-23	0.00	7.11	1.89	
28-Aug-23	3-Sep-23	6-Sep-23	0.00	11.79	2.52	
4-Sep-23	10-Sep-23	20-Sep-23	-0.77	20.71	10.01	Boiler shutdown 05/09/2023 - 08/09/2023
11-Sep-23	17-Sep-23	20-Sep-23	0.00	8.79	2.57	
18-Sep-23	24-Sep-23	5-Oct-23	0.00	13.36	3.26	
25-Sep-23	1-Oct-23	5-Oct-23	0.01	19.81	2.96	Boiler shutdown 25/09/2023
2-Oct-23	8-Oct-23	19-Oct-23	0.00	15.70	3.05	
9-Oct-23	15-Oct-23	19-Oct-23	0.00	8.87	3.24	
16-Oct-23	22-Oct-23	14-Nov-23	-0.77	20.38	3.94	Boiler offline 16/10 & 19/10
23-Oct-23	29-Oct-23	14-Nov-23	0.00	20.16	5.10	Boiler offline 28/10 & 29/10
30-Oct-23	5-Nov-23	16-Nov-23	0.01	19.96	7.58	Boiler offline 01/11 & 02/11
6-Nov-23	12-Nov-23	16-Nov-23	1.58	20.20	13.30	Boiler offline 06/11, 07/11, 09/11, 10/11, 12/11
13-Nov-23	19-Nov-23	29-Nov-23	1.24	19.99	11.30	Annual shutdown boiler offline 13/11 - 19/11
20-Nov-23	26-Nov-23	29-Nov-23	No data	No data	No data	Annual shutdown boiler offline 20/11 - 26/11
27-Dec-23	3-Dec-23	13-Dec-23	No data	No data	No data	Annual shutdown boiler offline 27/11 - 03/12
4-Dec-23	10-Dec-23	13-Dec-23	1.21	20.11	5.37	Boiler startup at 0500 hrs
11-Dec-23	17-Dec-23	27-Dec-23	1.07	11.69	4.80	
18-Dec-23	24-Dec-23	27-Dec-23	1.50	20.11	12.79	Boiler shutdown 21/12 - 07/01
25-Dec-23	31-Dec-23	10-Jan-24	19.78	20.07	19.91	Boiler shutdown 21/12 - 31/12
1-Jan-24	7-Jan-24	10-Jan-24	2.51	20.25	12.79	Boiler shutdown 01/01 - 02/01-05/01 hrs
8-Jan-24	14-Jan-24	24-Jan-24	1.08	20.06	9.28	Boiler shutdown 12/01-22:00 - 14/01-00:00 hrs
15-Jan-24	21-Jan-24	24-Jan-24	-0.77	19.93	11.02	Boiler shutdown 19/01-22:00 - 21/01-00:00 hrs
22-Jan-24	28-Jan-24	7-Feb-24	1.65	19.99	10.37	Boiler shutdown 26/01 - 29/01
29-Jan-24	4-Feb-24	7-Feb-24	1.47	19.88	13.65	Boiler shutdown 31/01 - 04/02
5-Feb-24	11-Feb-24	21-Feb-24	1.19	19.88	10.95	Boiler shutdown 09/02 - 12/02
12-Feb-24	18-Feb-24	21-Feb-24	1.61	19.77	11.61	Boiler shutdown 16/02 - 18/02
19-Feb-24	25-Feb-24	6-Mar-24	1.32	20.02	10.31	Boiler shutdown 23/02 - 26/02
26-Feb-24	3-Mar-24	6-Mar-24	0.80	19.83	11.71	Boiler shutdown 03/03 - 04/04
4-Mar-24	10-Mar-24	20-Mar-24	2.26	19.82	10.65	Boiler shutdown 08/03 - 10/03
11-Mar-24	17-Mar-24	20-Mar-24	1.48	20.21	11.59	Boiler shutdown 15/03 - 17/03
18-Mar-24	24-Mar-24	3-Apr-24	1.85	20.05	14.22	Boiler shutdown 22/03 - 24/04
25-Mar-24	31-Mar-24	3-Apr-24	1.96	20.03	12.09	Boiler shutdown 29/03 - 30/04
1-Apr-24	7-Apr-24	17-Apr-24	2.17	19.97	14.42	Boiler shutdown 05/04-05/04
8-Apr-24	14-Apr-24	17-Apr-24	2.04	19.99	10.65	Boiler shutdown 12/04-15/04
15-Apr-24	21-Apr-24	1-May-24	1.47	20.25	12.38	Boiler shutdown 19/04-20/04
22-Apr-24	28-Apr-24	1-May-24	2.48	19.94	17.04	Boiler shutdown 23/04-23/04
29-Apr-24	5-May-24	15-May-24	1.76	19.98	12.54	Boiler shutdown 03/05 - 06/05
6-May-24	12-May-24	15-May-24	2.13	19.82	14.18	Boiler shutdown 10/05 - 13/05
13-May-24	19-May-24	29-May-24	2.33	20.08	11.00	Boiler shutdown 17/05 - 19/05
20-May-24	26-May-24	29-May-24	1.37	20.11	13.43	Boiler shutdown 24/05 - 26/05
27-May-24	2-Jun-24	12-Jun-24	NA	NA	NA	Maintenance Shutdown 27/05 - 02/06
3-Jun-24	9-Jun-24	12-Jun-24	0.34	20.06	8.87	Boiler Shutdown 07/06 - 10/06
10-Jun-24	16-Jun-24	26-Jun-24	0.00	20.11	10.64	
17-Jun-24	23-Jun-24	26-Jun-24	0.00	12.76	2.76	
24-Jun-24	30-Jun-24	10-Jul-24	0.00	19.79	2.93	
1-Jul-24	7-Jul-24	10-Jul-24	0.00	20.30	10.98	Boiler Shutdown 03/07 - 04/07, 06/07 - 09/07/2024
8-Jul-24	14-Jul-24	24-Jul-24	0.06	20.31	14.04	Boiler Shutdown 08/07 - 09/07/2024
15-Jul-24	21-Jul-24	24-Jul-24	0.00	10.76	2.41	Boiler Shutdown 10/07 - 13/07/2024
22-Jul-24	28-Jul-24	7-Aug-24	0.00	5.20	1.79	
28-Jul-24	4-Aug-24	7-Aug-24	0.00	9.51	2.40	
5-Aug-24	11-Aug-24	21-Aug-24	0.00	6.44	1.96	
12-Aug-24	18-Aug-24	21-Aug-24	0.01	20.31	10.76	Boiler Shutdown - 12/08 - 15/08

Sampling Point: Monitoring Point 8 - Injection Water Inlet, Background River Water Temperature
 Licencee Cape Byron Management Pty Ltd
 Location Condong Cogeneration Power Plant
 EPL No 20424
 Parameters Monitored Temperature (°C)
 Frequency & Method Fortnightly Representative Sample
 Limit/s Not Applicable - Background river data is used to determine temperature of cooling water discharged at monitoring point 9



Comments

Date Sampled & Received	Date Published	Temp (°C)	Notes
2-Jan-23	25-Jan-23	28.0	
16-Jan-23	25-Jan-23	28.0	
23-Jan-23	08-Feb-23	28.0	
6-Feb-23	08-Feb-23	28.0	
13-Feb-23	22-Feb-23	28.0	
26-Feb-23	08-Mar-23	28.0	
1-Mar-23	08-Mar-23	30.5	
13-Mar-23	22-Mar-23	30.5	
20-Mar-23	22-Mar-23	30.5	
27-Mar-23	05-Apr-23	30.5	
3-Apr-23	05-Apr-23	30.5	
10-Apr-23	19-Apr-23	30.5	
17-Apr-23	19-Apr-23	30.5	
24-Apr-23	03-May-23	30.5	
1-May-23	03-May-23	30.5	
8-May-23	17-May-23	30.5	
18-May-23	31-May-23	19.0	
4-Jun-23	14-Jun-23	19.0	
7-Jun-23	14-Jun-23	22.5	
12-Jun-23	14-Jun-23	20.0	
14-Jun-23	21-Jun-23	20.0	
21-Jun-23	26-Jun-23	20.0	
26-Jun-23	03-Jul-23	20.0	
3-Jul-23	09-Jul-23	21.5	
10-Jul-23	26-Jul-23	21.5	
17-Jul-23	26-Jul-23	21.5	
24-Jul-23	09-Aug-23	21.5	
30-Jul-23	09-Aug-23	21.5	
14-Aug-23	23-Aug-23	24.5	
20-Aug-23	23-Aug-23	24.5	
4-Sep-23	20-Sep-23	24.5	
16-Sep-23	20-Sep-23	24.5	
21-Sep-23	04-Oct-23	24.5	
14-Oct-23	19-Oct-23	24.5	
24-Oct-23	29-Oct-23	28.0	
30-Oct-23	16-Nov-23	28.0	
5-Nov-23	16-Nov-23	28.0	
17-Nov-23	26-Nov-23	28.0	
27-Nov-23	13-Dec-23	28.0	
3-Dec-23	13-Dec-23	28.0	
6-Dec-23	13-Dec-23	30.0	
11-Dec-23	27-Dec-23	29.5	
16-Dec-23	28-Dec-23	29.5	
17-Dec-23	29-Dec-23	29.5	
25-Dec-23	30-Dec-23	29.5	
31-Dec-23	07-Jan-24	29.5	
8-Jan-24	14-Jan-24	29.5	
15-Jan-24	16-Jan-24	26.0	
17-Jan-24	21-Jan-24	26.0	
21-Jan-24	21-Jan-24	29.5	
28-Jan-24	07-Feb-24	29.5	
4-Feb-24	07-Feb-24	27.0	
8-Feb-24	18-Feb-24	29.5	
19-Feb-24	03-Mar-24	29.5	
4-Mar-24	17-Mar-24	29.5	
18-Mar-24	31-Mar-24	29.5	
1-Apr-24	14-Apr-24	29.5	
15-Apr-24	28-Apr-24	29.5	
29-Apr-24	12-May-24	29.5	
19-May-24	21-May-24	20.0	
23-May-24	24-May-24	22.0	
27-May-24	12-Jun-24	22.0	
10-Jun-24	26-Jun-26	22.0	
16-Jun-24	26-Jun-24	22.0	
24-Jun-24	10-Jul-24	22.0	
10-Jul-24	24-Jul-04	22.0	
14-Jul-24	24-Jul-24	22.0	
22-Jul-24	07-Aug-24	22.0	
5-Aug-24	21-Aug-24	22.0	
11-Aug-24	21-Aug-24	22.0	

Sampling Point:

Monitoring Point 11 - Stockpile Stormwater Discharge

Licence: Cape Byron Management Pty Ltd
 Location: Condong Cogeneration Power Plant
 EPL No: 20424
 Parameter/s Monitored: Rainfall
 Frequency & Method: Continuous Auto Sampler



TIPPING GIUGE CONTINUOUS RAINFALL MONITORING					
Period From		Period To		Daily Rain	
Date	Time	Date	Time	Total (mm)	Max Intensity (mm/min)
Monday, 1 January 2024	9:01am	Tuesday, 2 January 2024	9:00am	84.4	2.2
Tuesday, 2 January 2024	9:01am	Wednesday, 3 January 2024	9:00am	43.4	2.4
Wednesday, 3 January 2024	9:01am	Thursday, 4 January 2024	9:00am	0.2	0.2
Thursday, 4 January 2024	9:01am	Friday, 5 January 2024	9:00am	0.0	0.0
Friday, 5 January 2024	9:01am	Saturday, 6 January 2024	9:00am	0.0	0.0
Saturday, 6 January 2024	9:01am	Sunday, 7 January 2024	9:00am	1.0	0.4
Sunday, 7 January 2024	9:01am	Monday, 8 January 2024	9:00am	0.4	0.2
Monday, 8 January 2024	9:01am	Tuesday, 9 January 2024	9:00am	4.2	0.2
Tuesday, 9 January 2024	9:01am	Wednesday, 10 January 2024	9:00am	59.2	1.4
Wednesday, 10 January 2024	9:01am	Thursday, 11 January 2024	9:00am	2.0	0.2
Thursday, 11 January 2024	9:01am	Friday, 12 January 2024	9:00am	0.0	0.0
Friday, 12 January 2024	9:01am	Saturday, 13 January 2024	9:00am	4.6	0.6
Saturday, 13 January 2024	9:01am	Sunday, 14 January 2024	9:00am	1.8	0.2
Sunday, 14 January 2024	9:01am	Monday, 15 January 2024	9:00am	0.0	0.0
Monday, 15 January 2024	9:01am	Tuesday, 16 January 2024	9:00am	3.4	0.6
Tuesday, 16 January 2024	9:01am	Wednesday, 17 January 2024	9:00am	110.8	1.2
Wednesday, 17 January 2024	9:01am	Thursday, 18 January 2024	9:00am	50.4	0.8
Thursday, 18 January 2024	9:01am	Friday, 19 January 2024	9:00am	1.0	0.2
Friday, 19 January 2024	9:01am	Saturday, 20 January 2024	9:00am	9.0	0.2
Saturday, 20 January 2024	9:01am	Sunday, 21 January 2024	9:00am	0.4	0.2
Sunday, 21 January 2024	9:01am	Monday, 22 January 2024	9:00am	0.0	0.0
Monday, 22 January 2024	9:01am	Tuesday, 23 January 2024	9:00am	0.0	0.0
Tuesday, 23 January 2024	9:01am	Wednesday, 24 January 2024	9:00am	0.0	0.0
Wednesday, 24 January 2024	9:01am	Thursday, 25 January 2024	9:00am	0.0	0.0
Thursday, 25 January 2024	9:01am	Friday, 26 January 2024	9:00am	0.0	0.0
Friday, 26 January 2024	9:01am	Saturday, 27 January 2024	9:00am	0.0	0.0
Saturday, 27 January 2024	9:01am	Sunday, 28 January 2024	9:00am	0.0	0.0
Sunday, 28 January 2024	9:01am	Monday, 29 January 2024	9:00am	10.2	0.2
Monday, 29 January 2024	9:01am	Tuesday, 30 January 2024	9:00am	8.6	0.4
Tuesday, 30 January 2024	9:01am	Wednesday, 31 January 2024	9:00am	10.2	0.6
Wednesday, 31 January 2024	9:01am	Thursday, 1 February 2024	9:00am	0.4	0.2
Thursday, 1 February 2024	9:01am	Friday, 2 February 2024	9:00am	1.8	0.4
Friday, 2 February 2024	9:01am	Saturday, 3 February 2024	9:00am	0.0	0.0
Saturday, 3 February 2024	9:01am	Sunday, 4 February 2024	9:00am	0.0	0.0
Sunday, 4 February 2024	9:01am	Monday, 5 February 2024	9:00am	1.0	0.2
Monday, 5 February 2024	9:01am	Tuesday, 6 February 2024	9:00am	0.2	0.2
Tuesday, 6 February 2024	9:01am	Wednesday, 7 February 2024	9:00am	0.0	0.0
Wednesday, 7 February 2024	9:01am	Thursday, 8 February 2024	9:00am	0.0	0.0
Thursday, 8 February 2024	9:01am	Friday, 9 February 2024	9:00am	22.6	0.4
Friday, 9 February 2024	9:01am	Saturday, 10 February 2024	9:00am	8.0	0.2
Saturday, 10 February 2024	9:01am	Sunday, 11 February 2024	9:00am	4.2	0.2
Sunday, 11 February 2024	9:01am	Monday, 12 February 2024	9:00am	16.8	0.6
Monday, 12 February 2024	9:01am	Tuesday, 13 February 2024	9:00am	2.2	0.4
Tuesday, 13 February 2024	9:01am	Wednesday, 14 February 2024	9:00am	0.6	0.2
Wednesday, 14 February 2024	9:01am	Thursday, 15 February 2024	9:00am	0.0	0.0
Thursday, 15 February 2024	9:01am	Friday, 16 February 2024	9:00am	0.0	0.0
Friday, 16 February 2024	9:01am	Saturday, 17 February 2024	9:00am	55.0	1.2
Saturday, 17 February 2024	9:01am	Sunday, 18 February 2024	9:00am	15.8	1.2
Sunday, 18 February 2024	9:01am	Monday, 19 February 2024	9:00am	1.8	0.6
Monday, 19 February 2024	9:01am	Tuesday, 20 February 2024	9:00am	2.0	0.2
Tuesday, 20 February 2024	9:01am	Wednesday, 21 February 2024	9:00am	23.6	3.0
Wednesday, 21 February 2024	9:01am	Thursday, 22 February 2024	9:00am	1.4	0.4
Thursday, 22 February 2024	9:01am	Friday, 23 February 2024	9:00am	0.0	0.0
Friday, 23 February 2024	9:01am	Saturday, 24 February 2024	9:00am	0.0	0.0
Saturday, 24 February 2024	9:01am	Sunday, 25 February 2024	9:00am	0.0	0.0
Sunday, 25 February 2024	9:01am	Monday, 26 February 2024	9:00am	11.0	0.8
Monday, 26 February 2024	9:01am	Tuesday, 27 February 2024	9:00am	13.2	1.0
Tuesday, 27 February 2024	9:01am	Wednesday, 28 February 2024	9:00am	0.0	0.0
Wednesday, 28 February 2024	9:01am	Thursday, 29 February 2024	9:00am	0.0	0.0
Thursday, 29 February 2024	9:01am	Friday, 1 March 2024	9:00am	0.0	0.0
Friday, 1 March 2024	9:01am	Saturday, 2 March 2024	9:00am	0.0	0.0
Saturday, 2 March 2024	9:01am	Sunday, 3 March 2024	9:00am	0.0	0.0
Sunday, 3 March 2024	9:01am	Monday, 4 March 2024	9:00am	0.0	0.0
Monday, 4 March 2024	9:01am	Tuesday, 5 March 2024	9:00am	2.6	0.6
Tuesday, 5 March 2024	9:01am	Wednesday, 6 March 2024	9:00am	31.4	1.4
Wednesday, 6 March 2024	9:01am	Thursday, 7 March 2024	9:00am	1.0	0.4
Thursday, 7 March 2024	9:01am	Friday, 8 March 2024	9:00am	0.0	0.0
Friday, 8 March 2024	9:01am	Saturday, 9 March 2024	9:00am	1.8	0.4
Saturday, 9 March 2024	9:01am	Sunday, 10 March 2024	9:00am	2.4	0.4
Sunday, 10 March 2024	9:01am	Monday, 11 March 2024	9:00am	0.0	0.0
Monday, 11 March 2024	9:01am	Tuesday, 12 March 2024	9:00am	0.4	0.2
Tuesday, 12 March 2024	9:01am	Wednesday, 13 March 2024	9:00am	5.0	0.6
Wednesday, 13 March 2024	9:01am	Thursday, 14 March 2024	9:00am	0.6	0.2
Thursday, 14 March 2024	9:01am	Friday, 15 March 2024	9:00am	0.0	0.0
Friday, 15 March 2024	9:01am	Saturday, 16 March 2024	9:00am	0.0	0.0
Saturday, 16 March 2024	9:01am	Sunday, 17 March 2024	9:00am	13.4	0.6
Sunday, 17 March 2024	9:01am	Monday, 18 March 2024	9:00am	2.4	0.2
Monday, 18 March 2024	9:01am	Tuesday, 19 March 2024	9:00am	8.6	0.4
Tuesday, 19 March 2024	9:01am	Wednesday, 20 March 2024	9:00am	7.8	0.2
Wednesday, 20 March 2024	9:01am	Thursday, 21 March 2024	9:00am	7.4	0.8
Thursday, 21 March 2024	9:01am	Friday, 22 March 2024	9:00am	4.2	0.2
Friday, 22 March 2024	9:01am	Saturday, 23 March 2024	9:00am	1.4	0.2
Saturday, 23 March 2024	9:01am	Sunday, 24 March 2024	9:00am	0.0	0.0
Sunday, 24 March 2024	9:01am	Monday, 25 March 2024	9:00am	0.0	0.0
Monday, 25 March 2024	9:01am	Tuesday, 26 March 2024	9:00am	10.8	0.2
Tuesday, 26 March 2024	9:01am	Wednesday, 27 March 2024	9:00am	4.2	0.2
Wednesday, 27 March 2024	9:01am	Thursday, 28 March 2024	9:00am	47.0	0.4
Thursday, 28 March 2024	9:01am	Friday, 29 March 2024	9:00am	1.8	0.2
Friday, 29 March 2024	9:01am	Saturday, 30 March 2024	9:00am	0.8	0.2
Saturday, 30 March 2024	9:01am	Sunday, 31 March 2024	9:00am	11.8	0.8
Sunday, 31 March 2024	9:01am	Monday, 1 April 2024	9:00am	0.0	0.0
Monday, 1 April 2024	9:01am	Tuesday, 2 April 2024	9:00am	0.0	0.0
Tuesday, 2 April 2024	9:01am	Wednesday, 3 April 2024	9:00am	0.0	0.0
Wednesday, 3 April 2024	9:01am	Thursday, 4 April 2024	9:00am	0.0	0.0
Thursday, 4 April 2024	9:01am	Friday, 5 April 2024	9:00am	38.0	0.8
Friday, 5 April 2024	9:01am	Saturday, 6 April 2024	9:00am	15.0	0.4
Saturday, 6 April 2024	9:01am	Sunday, 7 April 2024	9:00am	12.0	0.2
Sunday, 7 April 2024	9:01am	Monday, 8 April 2024	9:00am	44.4	1.2
Monday, 8 April 2024	9:01am	Tuesday, 9 April 2024	9:00am	3.0	0.6
Tuesday, 9 April 2024	9:01am	Wednesday, 10 April 2024	9:00am	0.0	0.0
Wednesday, 10 April 2024	9:01am	Thursday, 11 April 2024	9:00am	0.0	0.0
Thursday, 11 April 2024	9:01am	Friday, 12 April 2024	9:00am	0.0	0.0
Friday, 12 April 2024	9:01am	Saturday, 13 April 2024	9:00am	0.0	0.0
Saturday, 13 April 2024	9:01am	Sunday, 14 April 2024	9:00am	0.0	0.0
Sunday, 14 April 2024	9:01am	Monday, 15 April 2024	9:00am	0.0	0.0
Monday, 15 April 2024	9:01am	Tuesday, 16 April 2024	9:00am	0.0	0.0
Tuesday, 16 April 2024	9:01am	Wednesday, 17 April 2024	9:00am	0.0	0.0
Wednesday, 17 April 2024	9:01am	Thursday, 18 April 2024	9:00am	0.0	0.0
Thursday, 18 April 2024	9:01am	Friday, 19 April 2024	9:00am	0.0	0.0
Friday, 19 April 2024	9:01am	Saturday, 20 April 2024	9:00am	2.4	0.2
Saturday, 20 April 2024	9:01am	Sunday, 21 April 2024	9:00am	0.0	0.0
Sunday, 21 April 2024	9:01am	Monday, 22 April 2024	9:00am	30.6	0.4
Monday, 22 April 2024	9:01am	Tuesday, 23 April 2024	9:00am	41.2	1.4
Tuesday, 23 April 2024	9:01am	Wednesday, 24 April 2024	9:00am	11.8	0.6
Wednesday, 24 April 2024	9:01am	Thursday, 25 April 2024	9:00am	2.0	1.8
Thursday, 25 April 2024	9:01am	Friday, 26 April 2024	9:00am	0.2	0.2

Sampling Point: Monitoring Point 11 - Stockpile Stormwater Discharge
Licence: Cape Environmental Pty Ltd
Location: Condong Cogeneration Power Plant
EPL No: 20424
Parameter/s Monitored: Rainfall
Frequency & Method: Continuous Auto Sampler



TIPPING GIUGE CONTINUOUS RAINFALL MONITORING					
Period From		Period To		Daily Rain	
Date	Time	Date	Time	Total (mm)	Max Intensity (mm/min)
Friday, 26 April 2024	9:01am	Saturday, 27 April 2024	9:00am	0.0	0.0
Saturday, 27 April 2024	9:01am	Sunday, 28 April 2024	9:00am	0.4	0.2
Sunday, 28 April 2024	9:01am	Monday, 29 April 2024	9:00am	0.8	0.2
Monday, 29 April 2024	9:01am	Tuesday, 30 April 2024	9:00am	11.4	0.8
Tuesday, 30 April 2024	9:01am	Wednesday, 1 May 2024	9:00am	0.2	0.2
Wednesday, 1 May 2024	9:01am	Thursday, 2 May 2024	9:00am	0.2	0.2
Thursday, 2 May 2024	9:01am	Friday, 3 May 2024	9:00am	2.2	0.2
Friday, 3 May 2024	9:01am	Saturday, 4 May 2024	9:00am	6.0	0.4
Saturday, 4 May 2024	9:01am	Sunday, 5 May 2024	9:00am	2.0	0.2
Sunday, 5 May 2024	9:01am	Monday, 6 May 2024	9:00am	0.2	0.2
Monday, 6 May 2024	9:01am	Tuesday, 7 May 2024	9:00am	2.8	0.2
Tuesday, 7 May 2024	9:01am	Wednesday, 8 May 2024	9:00am	16.0	0.8
Wednesday, 8 May 2024	9:01am	Thursday, 9 May 2024	9:00am	7.0	1.0
Thursday, 9 May 2024	9:01am	Friday, 10 May 2024	9:00am	11.8	0.8
Friday, 10 May 2024	9:01am	Saturday, 11 May 2024	9:00am	9.6	1.0
Saturday, 11 May 2024	9:01am	Sunday, 12 May 2024	9:00am	7.2	0.4
Sunday, 12 May 2024	9:01am	Monday, 13 May 2024	9:00am	15.8	1.0
Monday, 13 May 2024	9:01am	Tuesday, 14 May 2024	9:00am	0.2	0.6
Tuesday, 14 May 2024	9:01am	Wednesday, 15 May 2024	9:00am	0.2	0.2
Wednesday, 15 May 2024	9:01am	Thursday, 16 May 2024	9:00am	0.2	0.4
Thursday, 16 May 2024	9:01am	Friday, 17 May 2024	9:00am	0.4	11.2
Friday, 17 May 2024	9:01am	Saturday, 18 May 2024	9:00am	0.6	9.0
Saturday, 18 May 2024	9:01am	Sunday, 19 May 2024	9:00am	0.2	0.6
Sunday, 19 May 2024	9:01am	Monday, 20 May 2024	9:00am	0.4	5.4
Monday, 20 May 2024	9:01am	Tuesday, 21 May 2024	9:00am	0.0	0.0
Tuesday, 21 May 2024	9:01am	Wednesday, 22 May 2024	9:00am	0.0	0.0
Wednesday, 22 May 2024	9:01am	Thursday, 23 May 2024	9:00am	0.0	0.0
Thursday, 23 May 2024	9:01am	Friday, 24 May 2024	9:00am	0.2	0.2
Friday, 24 May 2024	9:01am	Saturday, 25 May 2024	9:00am	0.0	0.0
Saturday, 25 May 2024	9:01am	Sunday, 26 May 2024	9:00am	0.4	2.8
Sunday, 26 May 2024	9:01am	Monday, 27 May 2024	9:00am	2.4	0.4
Monday, 27 May 2024	9:01am	Tuesday, 28 May 2024	9:00am	0.2	0.2
Tuesday, 28 May 2024	9:01am	Wednesday, 29 May 2024	9:00am	0.2	0.2
Wednesday, 29 May 2024	9:01am	Thursday, 30 May 2024	9:00am	0.2	0.2
Thursday, 30 May 2024	9:01am	Friday, 31 May 2024	9:00am	0.2	0.2
Friday, 31 May 2024	9:01am	Saturday, 1 June 2024	9:00am	7.4	0.8
Saturday, 1 June 2024	9:01am	Sunday, 2 June 2024	9:00am	0.0	0.0
Sunday, 2 June 2024	9:01am	Monday, 3 June 2024	9:00am	0.0	0.4
Monday, 3 June 2024	9:01am	Tuesday, 4 June 2024	9:00am	0.4	0.2
Tuesday, 4 June 2024	9:01am	Wednesday, 5 June 2024	9:00am	0.0	0.0
Wednesday, 5 June 2024	9:01am	Thursday, 6 June 2024	9:00am	0.0	0.0
Thursday, 6 June 2024	9:01am	Friday, 7 June 2024	9:00am	0.2	0.2
Friday, 7 June 2024	9:01am	Saturday, 8 June 2024	9:00am	0.2	0.2
Saturday, 8 June 2024	9:01am	Sunday, 9 June 2024	9:00am	0.2	0.2
Sunday, 9 June 2024	9:01am	Monday, 10 June 2024	9:00am	0.0	0.0
Monday, 10 June 2024	9:01am	Tuesday, 11 June 2024	9:00am	0.2	0.2
Tuesday, 11 June 2024	9:01am	Wednesday, 12 June 2024	9:00am	0.0	0.0
Wednesday, 12 June 2024	9:01am	Thursday, 13 June 2024	9:00am	0.0	0.0
Thursday, 13 June 2024	9:01am	Friday, 14 June 2024	9:00am	0.0	0.0
Friday, 14 June 2024	9:01am	Saturday, 15 June 2024	9:00am	0.0	0.0
Saturday, 15 June 2024	9:01am	Sunday, 16 June 2024	9:00am	0.2	0.2
Sunday, 16 June 2024	9:01am	Monday, 17 June 2024	9:00am	0.0	0.0
Monday, 17 June 2024	9:01am	Tuesday, 18 June 2024	9:00am	0.0	0.0
Tuesday, 18 June 2024	9:01am	Wednesday, 19 June 2024	9:00am	0.0	0.0
Wednesday, 19 June 2024	9:01am	Thursday, 20 June 2024	9:00am	0.0	0.0
Thursday, 20 June 2024	9:01am	Friday, 21 June 2024	9:00am	0.0	0.0
Friday, 21 June 2024	9:01am	Saturday, 22 June 2024	9:00am	0.0	0.0
Saturday, 22 June 2024	9:01am	Sunday, 23 June 2024	9:00am	0.0	0.0
Sunday, 23 June 2024	9:01am	Monday, 24 June 2024	9:00am	0.0	0.0
Monday, 24 June 2024	9:01am	Tuesday, 25 June 2024	9:00am	0.0	0.0
Tuesday, 25 June 2024	9:01am	Wednesday, 26 June 2024	9:00am	1.0	0.2
Wednesday, 26 June 2024	9:01am	Thursday, 27 June 2024	9:00am	0.8	0.2
Thursday, 27 June 2024	9:01am	Friday, 28 June 2024	9:00am	0.0	0.0
Friday, 28 June 2024	9:01am	Saturday, 29 June 2024	9:00am	4.6	0.6
Saturday, 29 June 2024	9:01am	Sunday, 30 June 2024	9:00am	0.0	0.0
Sunday, 30 June 2024	9:01am	Monday, 1 July 2024	9:00am	0.0	0.0
Monday, 1 July 2024	9:01am	Tuesday, 2 July 2024	9:00am	2.4	0.4
Tuesday, 2 July 2024	9:01am	Wednesday, 3 July 2024	9:00am	15.2	0.2
Wednesday, 3 July 2024	9:01am	Thursday, 4 July 2024	9:00am	16.4	0.4
Thursday, 4 July 2024	9:01am	Friday, 5 July 2024	9:00am	25.6	0.8
Friday, 5 July 2024	9:01am	Saturday, 6 July 2024	9:00am	3.0	0.2
Saturday, 6 July 2024	9:01am	Sunday, 7 July 2024	9:00am	22.4	1.0
Sunday, 7 July 2024	9:01am	Monday, 8 July 2024	9:00am	1.4	0.2
Monday, 8 July 2024	9:01am	Tuesday, 9 July 2024	9:00am	0.6	0.2
Tuesday, 9 July 2024	9:01am	Wednesday, 10 July 2024	9:00am	2.8	0.2
Wednesday, 10 July 2024	9:01am	Thursday, 11 July 2024	9:00am	1.0	0.2
Thursday, 11 July 2024	9:01am	Friday, 12 July 2024	9:00am	7.0	1.4
Friday, 12 July 2024	9:01am	Saturday, 13 July 2024	9:00am	0.0	0.0
Saturday, 13 July 2024	9:01am	Sunday, 14 July 2024	9:00am	0.2	0.2
Sunday, 14 July 2024	9:01am	Monday, 15 July 2024	9:00am	0.0	0.0
Monday, 15 July 2024	9:01am	Tuesday, 16 July 2024	9:00am	0.0	0.0
Tuesday, 16 July 2024	9:01am	Wednesday, 17 July 2024	9:00am	0.0	0.0
Wednesday, 17 July 2024	9:01am	Thursday, 18 July 2024	9:00am	0.0	0.0
Thursday, 18 July 2024	9:01am	Friday, 19 July 2024	9:00am	0.0	0.0
Friday, 19 July 2024	9:01am	Saturday, 20 July 2024	9:00am	0.0	0.0
Saturday, 20 July 2024	9:01am	Sunday, 21 July 2024	9:00am	0.0	0.0
Sunday, 21 July 2024	9:01am	Monday, 22 July 2024	9:00am	0.0	0.0
Monday, 22 July 2024	9:01am	Tuesday, 23 July 2024	9:00am	0.0	0.0
Tuesday, 23 July 2024	9:01am	Wednesday, 24 July 2024	9:00am	0.0	0.0
Wednesday, 24 July 2024	9:01am	Thursday, 25 July 2024	9:00am	0.0	0.0
Thursday, 25 July 2024	9:01am	Friday, 26 July 2024	9:00am	1.0	0.2
Friday, 26 July 2024	9:01am	Saturday, 27 July 2024	9:00am	0.0	0.0
Saturday, 27 July 2024	9:01am	Sunday, 28 July 2024	9:00am	0.0	0.0
Sunday, 28 July 2024	9:01am	Monday, 29 July 2024	9:00am	0.0	0.0
Monday, 29 July 2024	9:01am	Tuesday, 30 July 2024	9:00am	0.0	0.0
Tuesday, 30 July 2024	9:01am	Wednesday, 31 July 2024	9:00am	0.0	0.0
Wednesday, 31 July 2024	9:01am	Thursday, 1 August 2024	9:00am	0.0	0.0
Thursday, 1 August 2024	9:01am	Friday, 2 August 2024	9:00am	0.0	0.0
Friday, 2 August 2024	9:01am	Saturday, 3 August 2024	9:00am	0.0	0.0
Saturday, 3 August 2024	9:01am	Sunday, 4 August 2024	9:00am	0.0	0.0
Sunday, 4 August 2024	9:01am	Monday, 5 August 2024	9:00am	0.0	0.0
Monday, 5 August 2024	9:01am	Tuesday, 6 August 2024	9:00am	0.0	0.0
Tuesday, 6 August 2024	9:01am	Wednesday, 7 August 2024	9:00am	0.4	0.2
Wednesday, 7 August 2024	9:01am	Thursday, 8 August 2024	9:00am	0.0	0.0
Thursday, 8 August 2024	9:01am	Friday, 9 August 2024	9:00am	0.0	0.0
Friday, 9 August 2024	9:01am	Saturday, 10 August 2024	9:00am	3.4	0.2
Saturday, 10 August 2024	9:01am	Sunday, 11 August 2024	9:00am	0.0	0.0
Sunday, 11 August 2024	9:01am	Monday, 12 August 2024	9:00am	0.6	0.2
Monday, 12 August 2024	9:01am	Tuesday, 13 August 2024	9:00am	0.0	1.6
Tuesday, 13 August 2024	9:01am	Wednesday, 14 August 2024	9:00am	32.0	0.0
Wednesday, 14 August 2024	9:01am	Thursday, 15 August 2024	9:00am	17.8	0.4
Thursday, 15 August 2024	9:01am	Friday, 16 August 2024	9:00am	32.6	0.8
Friday, 16 August 2024	9:01am	Saturday, 17 August 2024	9:00am	8.0	0.2
Saturday, 17 August 2024	9:01am	Sunday, 18 August 2024	9:00am	1.6	0.2
Sunday, 18 August 2024	9:01am	Monday, 19 August 2024	9:00am	0.0	0.0

Sampling Point
Location
County
City, St.
Neighborhood
Site Name

Wastewater Plant # 3 - Georgetown Cooling Water Discharge
Case No. Management Plan No.
CWA/COP/Compliance Plan
Date



Date Sampled	Date Received	Date Published	Parameter	BOD ₅ (mg/L)		TSS (mg/L)		Phosphorus (mg/L)		Nitrogen (mg/L)		Notes
				NO	NA	NO	NA	NO	NA	NO	NA	
15-Jan-23	16-Jan-23	25-Jan-23		3.9	NA	0.42	NA	0.3	0.22			
16-Jan-23	17-Jan-23	26-Jan-23		3.11	NA	0.76	NA	0.29	0.16			
16-Jan-23	17-Jan-23	26-Feb-23		15.2	7	0.44	NA	0.4	0.24			
23-Jan-23	01-Feb-23	06-Feb-23		1.8	7	0.41	0.55	0.14				
30-Jan-23	30-Jan-23	06-Feb-23		11.8	6	0.33	0.13	0.22				
30-Feb-23	21-Feb-23	28-Feb-23		11.8	NA	1.11	2.3	0.35				
10-Feb-23	07-Feb-23	08-Mar-23		4.1	6	0.32	14.2	0.18				
20-Feb-23	21-Feb-23	08-Mar-23		11.8	NA	0.45	11.2	0.36				
27-Feb-23	26-Feb-23	08-Mar-23		11.8	6	0.3	14.3	0.17				
28-Feb-23	NA	28-Feb-23	NA	NA	NA	NA	NA	NA	NA		Not Available	
28-Mar-23	19-Mar-23	05-Apr-23		6.2	NA	0.33	16.4	0.17				
27-Mar-23	04-Apr-23	05-Apr-23		11.8	5	0.32	15.8	0.23				
28-Apr-23	15-Apr-23	16-Apr-23		2.1	5	0.24	16.2	0.14				
11-Apr-23	04-Apr-23	09-Apr-23		11.8	6	0.3	18.9	0.19				
20-Apr-23	20-Apr-23	09-May-23		7.2	5	0.26	16.7	0.08				
14-May-23	15-May-23	17-May-23		11.8	3	0.25	16.5	0.14				
08-May-23	04-May-23	21-May-23		15.1	7	0.27	16.1	0.27				
12-May-23	23-May-23	21-May-23		2.1	3	0.25	16.7	0.16				
20-May-23	07-Jun-23	16-Jun-23		2.7	2	0.26	16.8	0.14				
15-Jun-23	15-Jun-23	16-Jun-23		11.8	7	0.32	14.5	0.17				
13-Jun-23	20-Jun-23	28-Jun-23		11.8	3	0.26	16.6	0.21				
20-Jun-23	10-Jul-23	10-Jul-23		3.9	3	0.21	7.98	0.11				
02-Jul-23	02-Jul-23	26-Jul-23		2.7	3	0.26	7.98	0.01				
03-Jul-23	21-Jul-23	26-Jul-23		6.1	2	0.26	16.2	0.01				
10-Jul-23	27-Jul-23	09-Aug-23		2.7	2	0.43	14	0.03				
20-Jul-23	21-Jul-23	09-Aug-23		3.9	3	0.36	17.1	0.18				
20-Jul-23	07-Aug-23	09-Aug-23		11.8	3	0.36	15.8	0.19				
01-Aug-23	18-Aug-23	27-Aug-23		2.7	1	0.46	16.8	0.11				
16-Aug-23	16-Aug-23	27-Aug-23		1.8	7	0.33	16.1	0.03				
21-Aug-23	20-Aug-23	06-Sep-23		10	2	1.39	16.5	0.05				
28-Aug-23	05-Sep-23	28-Sep-23		2.4	4	1.85	9.21	0.19				
06-Sep-23	11-Sep-23	27-Sep-23		2.7	3	1.91	8.99	0.19				
16-Sep-23	26-Sep-23	05-Oct-23		2.4	9	0.47	9.2	0.04				
24-Sep-23	04-Oct-23	05-Oct-23		2.4	8	0.43	16.1	0.11				
02-Oct-23	10-Oct-23	16-Oct-23		5.1	6	1.87	14.8	0.05				
05-Oct-23	17-Oct-23	16-Oct-23		11.8	6	1.76	6.1	0.11				
10-Oct-23	27-Oct-23	17-Nov-23		1	15	1.31	17.1	0.07				
23-Oct-23	20-Oct-23	17-Nov-23		4.8	37	2.27	34.4	0.08				
20-Oct-23	13-Nov-23	16-Nov-23		4.2	18	1.51	12.3	0.04				
06-Nov-23	13-Nov-23	06-Nov-23		4.2	11	2.89	12	0.04				
13-Nov-23	17-Nov-23	06-Dec-23		11.8	NA	1.76	19.2	0.11				
20-Nov-23	NA	NA	NA	NA	NA	NA	NA	NA			Not Available	
05-Dec-23	13-Dec-23	13-Dec-23		2.1	26	0.7	4.66	0.04				
15-Dec-23	20-Dec-23	27-Dec-23		12	11	0.39	6.69	0.19				
16-Dec-23	27-Dec-23	29-Dec-23		2.7	16	0.59	6.69	0.04				
08-Jan-24	08-Jan-24	24-Jan-24		11.8	5	0.32	0.32	0.04				
08-Jan-24	08-Jan-24	24-Jan-24		1.2	6	0.38	6.3	0.11				
15-Jan-24	15-Jan-24	07-Feb-24		1.2	5	0.32	6.11	0.09				
20-Jan-24	27-Jan-24	27-Feb-24		11.8	7	1.89	5.84	0.07				
30-Jan-24	30-Jan-24	27-Feb-24		1.2	7	0.44	3.76	0.14				
08-Feb-24	08-Feb-24	21-Feb-24		3.9	12	0.63	6.39	0.11				
15-Feb-24	14-Feb-24	28-Feb-24		1.2	6	0.39	4.36	0.11				
16-Feb-24	14-Feb-24	08-Mar-24		2.7	5	0.97	4.36	0.17				
20-Feb-24	16-Feb-24	08-Mar-24		4.1	5	0.41	8.92	0.14				
04-Mar-24	13-Mar-24	20-Mar-24		2.1	9	0.6	4.65	0.05				
11-Mar-24	20-Mar-24	23-Mar-24		3.9	10	0.41	8.94	0.04				
20-Mar-24	20-Mar-24	03-Apr-24		1.2	4	0.39	10.2	0.14				
20-Mar-24	20-Mar-24	03-Apr-24		1.2	6	0.4	9.71	0.07				
03-Apr-24	04-Apr-24	03-Apr-24		1.2	9	0.72	12.4	0.11				
11-Apr-24	11-Apr-24	03-May-24		2.1	5	0.43	6.71	0.07				
17-Apr-24	17-Apr-24	03-May-24		11.8	5	0.48	7.69	0.11				
20-Apr-24	20-Apr-24	03-May-24		6.1	6	0.47	15.8	0.01				
17-May-24	17-May-24	13-Jun-24		11.8	2	0.46	12.3	0.03				
08-May-24	11-May-24	12-Jun-24		1.2	4	0.41	12.6	0.04				
14-May-24	24-May-24	12-Jun-24		11.8	4	0.32	12.3	0.08				
21-May-24	23-May-24	12-Jun-24		11.8	4	0.34	26.8	0.11				
03-Jun-24	03-Jun-24	12-Jun-24		1.2	3	1.41	17.5	0.01				
11-Jun-24	13-Jun-24	12-Jun-24		2.4	3	0.24	6.39	0.07				
18-Jun-24	19-Jun-24	26-Jun-24		11.8	4	0.4	8.89	0.01				
26-Jun-24	26-Jun-24	26-Jun-24		2.7	5	0.59	16.9	0.04				
03-Jul-24	03-Jul-24	09-Jul-24		4.1	4	0.36	16.6	0.01				
10-Jul-24	10-Jul-24	26-Jul-24		11.8	6	0.37	6.37	0.07				
15-Jul-24	15-Jul-24	27-Aug-24		11.8	1	0.2	6.37	0.07				
20-Jul-24	20-Jul-24	07-Sep-24		1.2	3	0.3	20.7	0.09				
20-Jul-24	20-Jul-24	07-Sep-24		2.1	2	0.36	15.9	0.14				
04-Aug-24	04-Aug-24	27-Aug-24		2.1	6	0.63	17.6	0				
15-Aug-24	15-Aug-24	21-Aug-24		1.2	1	1.11	21.3	0.01				
15-Jan-24											0.09	

Notes: Total Residual Chlorine analysis is performed on-site immediately from a grab sample. Therefore the results are recorded on the date of sampling.

Sampling Point: Monitoring Point 12 - Stormwater Discharge From Stockpile Catchment Basin
 Licence: Cape Byron Management Pty Ltd
 Location: Condong Cogeneration Power Plant
 EPL No: 20424
 Parameter/s Monitored: See Table
 Frequency & Method: Sampling any discharge, whether controlled or otherwise, which has not occurred from rainfall exceeding 82mm over any consecutive five day period
 Limit/s: See Table
 Comments: A 90 percentile limit means 90% of results must comply with the specified limit. No result may exceed the maximum limit.



Date Sampled	Date Received	Date Published						Notes	
			BOD ₅ (mg/L)	Nitrogen (mg/L)	pH	Phosphorus (mg/L)	TSS (mg/L)		
			90 Percentile Limit	30	10				
			Maximum Limit	55	20	6.5 - 8.5	No Limit	50.0	
19-Jan-21	28-Jan-21	29-Jan-21		8.2	1.3	7.88	0.3	32.0	
23-Feb-21	01-Mar-21	12-Mar-21		10.0	2.1	7.17	0.9	37.0	
15-Mar-21	22-Mar-21	08-Apr-21		5.5	1.2	7.47	0.5	44.0	
25-Mar-21	31-Mar-21	08-Apr-21		15.0	0.9	6.99	0.4	38.0	
13-May-21	19-May-21	02-Jun-21		3.7	0.8	7.65	0.2	11.0	
09-Jul-21	14-Jul-21	16-Jul-21		9.7	1.0	6.89	0.2	37.0	
13-Oct-21	20-Oct-21	22-Oct-21		15.0	1.0	7.15	0.2	27.0	
08-Dec-21	15-Dec-21	22-Dec-21		6.6	1.3	7.60	0.4	17.0	
30-Dec-21	05-Jan-22	14-Jan-22		5.2	0.8	7.35	0.2	23.0	
13-May-22	18-May-22	31-May-22		2.8	2.0	7.15	0.3	28.0	
22-Jul-22	27-Jul-22	02-Aug-22		<1.0	1.0	7.27	0.3	40.0	
27-Jul-22	08-Aug-22	10-Aug-22		8.5	0.9	6.80	0.4	44.0	
26-Sep-22	04-Oct-22	05-Oct-22		3.0	0.9	7.18	0.2	38.0	
03-Nov-22	11-Nov-22	16-Nov-22		5.4	1.1	8.50	0.2	30.0	
13-Nov-23	21-Nov-23	29-Nov-23		8.5	2.0	8.50	0.2	16.0	
04-Jan-24	16-Jan-24	24-Jan-24		12.3	2.1	6.78	0.7	28.0	
22-Jan-24	01-Feb-24	07-Feb-24		8.0	1.6	7.27	0.6	34.0	
22-Feb-24	29-Feb-24	06-Mar-24		5.5	1.3	7.32	0.3	16.0	
08-Apr-24	15-Apr-24	17-Apr-24		6.0	1.6	7.20	0.4	33.0	
22-Jul-24	01-Aug-24	07-Aug-24		10.3	2.8	7.00	0.4	2.82	



© 2018 by the author(s). All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the author(s).

This work is licensed under a Creative Commons Attribution-NonCommercial-ShareAlike 4.0 International License. For more information, see <http://creativecommons.org/licenses/by-nc-sa/4.0/>.

Accounting Period: Working Period 6 - Experimental Learning Month (December)
 Location: Day 601 - Management 701-01
 Course: General Management/Accounting Area
 W. No.: 2002
 Department: Business Administration
 Program & Section: Business Admin

Accounting Period	Date	Time	Instructor	Experimental Learning Month (December)										Notes									
				1	2	3	4	5	6	7	8	9	10										
12/01/18	12/01/18	08:00-10:00	Dr. [Name]	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	1.10	1.11	1.12	1.13	1.14	1.15	1.16	1.17	1.18	1.19	1.20
12/02/18	12/02/18	08:00-10:00	Dr. [Name]	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	2.10	2.11	2.12	2.13	2.14	2.15	2.16	2.17	2.18	2.19	2.20
12/03/18	12/03/18	08:00-10:00	Dr. [Name]	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	3.10	3.11	3.12	3.13	3.14	3.15	3.16	3.17	3.18	3.19	3.20
12/04/18	12/04/18	08:00-10:00	Dr. [Name]	4.1	4.2	4.3	4.4	4.5	4.6	4.7	4.8	4.9	4.10	4.11	4.12	4.13	4.14	4.15	4.16	4.17	4.18	4.19	4.20
12/05/18	12/05/18	08:00-10:00	Dr. [Name]	5.1	5.2	5.3	5.4	5.5	5.6	5.7	5.8	5.9	5.10	5.11	5.12	5.13	5.14	5.15	5.16	5.17	5.18	5.19	5.20
12/06/18	12/06/18	08:00-10:00	Dr. [Name]	6.1	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9	6.10	6.11	6.12	6.13	6.14	6.15	6.16	6.17	6.18	6.19	6.20
12/07/18	12/07/18	08:00-10:00	Dr. [Name]	7.1	7.2	7.3	7.4	7.5	7.6	7.7	7.8	7.9	7.10	7.11	7.12	7.13	7.14	7.15	7.16	7.17	7.18	7.19	7.20
12/08/18	12/08/18	08:00-10:00	Dr. [Name]	8.1	8.2	8.3	8.4	8.5	8.6	8.7	8.8	8.9	8.10	8.11	8.12	8.13	8.14	8.15	8.16	8.17	8.18	8.19	8.20
12/09/18	12/09/18	08:00-10:00	Dr. [Name]	9.1	9.2	9.3	9.4	9.5	9.6	9.7	9.8	9.9	9.10	9.11	9.12	9.13	9.14	9.15	9.16	9.17	9.18	9.19	9.20
12/10/18	12/10/18	08:00-10:00	Dr. [Name]	10.1	10.2	10.3	10.4	10.5	10.6	10.7	10.8	10.9	10.10	10.11	10.12	10.13	10.14	10.15	10.16	10.17	10.18	10.19	10.20
12/11/18	12/11/18	08:00-10:00	Dr. [Name]	11.1	11.2	11.3	11.4	11.5	11.6	11.7	11.8	11.9	11.10	11.11	11.12	11.13	11.14	11.15	11.16	11.17	11.18	11.19	11.20
12/12/18	12/12/18	08:00-10:00	Dr. [Name]	12.1	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	12.10	12.11	12.12	12.13	12.14	12.15	12.16	12.17	12.18	12.19	12.20
12/13/18	12/13/18	08:00-10:00	Dr. [Name]	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	13.10	13.11	13.12	13.13	13.14	13.15	13.16	13.17	13.18	13.19	13.20
12/14/18	12/14/18	08:00-10:00	Dr. [Name]	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	14.10	14.11	14.12	14.13	14.14	14.15	14.16	14.17	14.18	14.19	14.20
12/15/18	12/15/18	08:00-10:00	Dr. [Name]	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	15.10	15.11	15.12	15.13	15.14	15.15	15.16	15.17	15.18	15.19	15.20
12/16/18	12/16/18	08:00-10:00	Dr. [Name]	16.1	16.2	16.3	16.4	16.5	16.6	16.7	16.8	16.9	16.10	16.11	16.12	16.13	16.14	16.15	16.16	16.17	16.18	16.19	16.20
12/17/18	12/17/18	08:00-10:00	Dr. [Name]	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.8	17.9	17.10	17.11	17.12	17.13	17.14	17.15	17.16	17.17	17.18	17.19	17.20
12/18/18	12/18/18	08:00-10:00	Dr. [Name]	18.1	18.2	18.3	18.4	18.5	18.6	18.7	18.8	18.9	18.10	18.11	18.12	18.13	18.14	18.15	18.16	18.17	18.18	18.19	18.20
12/19/18	12/19/18	08:00-10:00	Dr. [Name]	19.1	19.2	19.3	19.4	19.5	19.6	19.7	19.8	19.9	19.10	19.11	19.12	19.13	19.14	19.15	19.16	19.17	19.18	19.19	19.20
12/20/18	12/20/18	08:00-10:00	Dr. [Name]	20.1	20.2	20.3	20.4	20.5	20.6	20.7	20.8	20.9	20.10	20.11	20.12	20.13	20.14	20.15	20.16	20.17	20.18	20.19	20.20
12/21/18	12/21/18	08:00-10:00	Dr. [Name]	21.1	21.2	21.3	21.4	21.5	21.6	21.7	21.8	21.9	21.10	21.11	21.12	21.13	21.14	21.15	21.16	21.17	21.18	21.19	21.20
12/22/18	12/22/18	08:00-10:00	Dr. [Name]	22.1	22.2	22.3	22.4	22.5	22.6	22.7	22.8	22.9	22.10	22.11	22.12	22.13	22.14	22.15	22.16	22.17	22.18	22.19	22.20
12/23/18	12/23/18	08:00-10:00	Dr. [Name]	23.1	23.2	23.3	23.4	23.5	23.6	23.7	23.8	23.9	23.10	23.11	23.12	23.13	23.14	23.15	23.16	23.17	23.18	23.19	23.20
12/24/18	12/24/18	08:00-10:00	Dr. [Name]	24.1	24.2	24.3	24.4	24.5	24.6	24.7	24.8	24.9	24.10	24.11	24.12	24.13	24.14	24.15	24.16	24.17	24.18	24.19	24.20
12/25/18	12/25/18	08:00-10:00	Dr. [Name]	25.1	25.2	25.3	25.4	25.5	25.6	25.7	25.8	25.9	25.10	25.11	25.12	25.13	25.14	25.15	25.16	25.17	25.18	25.19	25.20
12/26/18	12/26/18	08:00-10:00	Dr. [Name]	26.1	26.2	26.3	26.4	26.5	26.6	26.7	26.8	26.9	26.10	26.11	26.12	26.13	26.14	26.15	26.16	26.17	26.18	26.19	26.20
12/27/18	12/27/18	08:00-10:00	Dr. [Name]	27.1	27.2	27.3	27.4	27.5	27.6	27.7	27.8	27.9	27.10	27.11	27.12	27.13	27.14	27.15	27.16	27.17	27.18	27.19	27.20
12/28/18	12/28/18	08:00-10:00	Dr. [Name]	28.1	28.2	28.3	28.4	28.5	28.6	28.7	28.8	28.9	28.10	28.11	28.12	28.13	28.14	28.15	28.16	28.17	28.18	28.19	28.20
12/29/18	12/29/18	08:00-10:00	Dr. [Name]	29.1	29.2	29.3	29.4	29.5	29.6	29.7	29.8	29.9	29.10	29.11	29.12	29.13	29.14	29.15	29.16	29.17	29.18	29.19	29.20
12/30/18	12/30/18	08:00-10:00	Dr. [Name]	30.1	30.2	30.3	30.4	30.5	30.6	30.7	30.8	30.9	30.10	30.11	30.12	30.13	30.14	30.15	30.16	30.17	30.18	30.19	30.20
12/31/18	12/31/18	08:00-10:00	Dr. [Name]	31.1	31.2	31.3	31.4	31.5	31.6	31.7	31.8	31.9	31.10	31.11	31.12	31.13	31.14	31.15	31.16	31.17	31.18	31.19	31.20

Licencee
Location
EPL No

Cape Byron Management Pty Ltd
Condong Power Plant
20424



MONITORING REPORT CORRECTIONS LOG

Date / Period	Monitoring Point	Pollutant/Parameter	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
31-Jan-22	9	Oxygen	Min. -0.95 Max. -0.93 Mean -0.93	Min. 2.92 Max. 20.14 Mean 16.44	18-May-22	11-Feb-22	Failed probe identified used back up probe data
7-Feb-22	9	Oxygen	Min. -0.95 Max. -0.93 Mean -0.94	Min. 3.56 Max. 20.54 Mean 12.46	18-May-22	11-Feb-22	Failed probe identified used back up probe data
14-Feb-22	9	Oxygen	Min. -0.95 Max. -0.93 Mean -0.94	Min. 1.97 Max. 20.28 Mean 13.54	18-May-22	25-Feb-22	Failed probe identified used back up probe data
21-Feb-22	9	Oxygen	NA	Min. 1.97 Max. 20.28 Mean 13.54	18-May-22	22-Apr-22	Failed probe identified used back up probe data
11 April - 30 April 22	9	pH Temp O2	None collected	As per sheet	18-Jul-22	01-May-22	Data recoverd from failed hard drive 11-30 April and updated to system on the 18/07/2022
3-Mar-24	2	PM10	15.10	10.10	28-May-24	01-May-24	mg per filter entred should be not micro gram cubic meter
9-Mar-24	2	PM10	21.50	14.20	28-May-24	01-May-24	mg per filter entred should be not micro gram cubic meter
15-Mar-24	2	PM10	29.20	19.40	28-May-24	01-May-24	mg per filter entred should be not micro gram cubic meter
23-Mar-24	2	PM10	21.60	14.20	28-May-24	01-May-24	mg per filter entred should be not micro gram cubic meter
27-Mar-24	2	PM10	6.80	4.50	28-May-24	01-May-24	mg per filter entred should be not micro gram cubic meter
15-Apr-24	9	pH	8.59	8.47	23-Jul-24	17-Apr-24	Incorrect data capture